

# APPENDIX A

## FACILITY INFORMATION

NPDES Permit Rating Worksheet

USGS Map

Site/Flow Diagram

Site Visit Memo

DMR Data

# NPDES PERMIT RATING WORK SHEET

NPDES NO. VA0076015

- Regular Addition
- Discretionary Addition
- Score change, but no status change
- Deletion

Facility Name: Ronile, Inc.

City: Rocky Mount

Receiving Water: Pigg River

Reach Number: \_\_\_\_\_

Is this facility a steam electric power plant (SIC=4911) with one or more of the following characteristics?

1. Power output 500 MW or greater (not using a cooling pond/lake)
  2. A nuclear power plant
  3. Cooling water discharge greater than 25% of the receiving stream's 7Q10 flow rate
- YES; score is 600 (stop here)  NO (continue)

Is this permit for a municipal separate storm sewer serving a population greater than 100,000?

- YES; score is 700 (stop here)  
 NO (continue)

## FACTOR 1: Toxic Pollutant Potential

PCS SIC Code: \_\_\_\_\_ Primary SIC Code: 2269 Other SIC Codes: 4961  
 Industrial Subcategory Code: 002 (Code 000 if no subcategory)

Determine the Toxicity potential from Appendix A. Be sure to use the TOTAL toxicity potential column and check one)

Toxicity Group	Code	Points	Toxicity Group	Code	Points	Toxicity Group	Code	Points
<input type="checkbox"/> No process waste streams	0	0	<input type="checkbox"/> 3.	3	15	<input type="checkbox"/> 7.	7	35
<input type="checkbox"/> 1.	1	5	<input type="checkbox"/> 4.	4	20	<input type="checkbox"/> 8.	8	40
<input type="checkbox"/> 2.	2	10	<input type="checkbox"/> 5.	5	25	<input checked="" type="checkbox"/> 9.	9	45
			<input type="checkbox"/> 6.	6	30	<input type="checkbox"/> 10.	10	50

Code Number Checked: 9

**Total Points Factor 1:** 45

## FACTOR 2: Flow/Stream Flow Volume (Complete either Section A or Section B; check only one)

Section A  Wastewater Flow Only Considered

Section B  Wastewater and Stream Flow Considered

Wastewater Type (See Instructions)	Code	Points
Type I: Flow < 5 MGD	<input type="checkbox"/> 11	0
Flow 5 to 10 MGD	<input type="checkbox"/> 12	10
Flow > 10 to 50 MGD	<input type="checkbox"/> 13	20
Flow > 50 MGD	<input type="checkbox"/> 14	30
Type II: Flow < 1 MGD	<input type="checkbox"/> 21	10
Flow 1 to 5 MGD	<input type="checkbox"/> 22	20
Flow > 5 to 10 MGD	<input type="checkbox"/> 23	30
Flow > 10 MGD	<input type="checkbox"/> 24	50
Type III: Flow < 1 MGD	<input type="checkbox"/> 31	0
Flow 1 to 5 MGD	<input type="checkbox"/> 32	10
Flow > 5 to 10 MGD	<input type="checkbox"/> 33	20
Flow > 10 MGD	<input type="checkbox"/> 34	30

Wastewater Type (See Instructions)	Percent of instream Wastewater Concentration at Receiving Stream Low Flow	Code	Points
Type I/III:	< 10 %	<input type="checkbox"/> 41	0
	10 % to < 50 %	<input type="checkbox"/> 42	10
	> 50 %	<input type="checkbox"/> 43	20
Type II:	< 10 %	<input checked="" type="checkbox"/> 51	0
	10 % to < 50 %	<input type="checkbox"/> 52	20
	> 50 %	<input type="checkbox"/> 53	30

Code Checked from Section A or B: 51

**Total Points Factor 2:** 0

**FACTOR 3: Conventional Pollutants**  
(only when limited by the permit)

NPDES NO: VA0076015

A. Oxygen Demanding Pollutant: (check one)     BOD     COD     Other: \_\_\_\_\_

Permit Limits: (check one)	<input type="checkbox"/>		Code	Points
	<input type="checkbox"/>	< 100 lbs/day	1	0
	<input type="checkbox"/>	100 to 1000 lbs/day	2	5
	<input checked="" type="checkbox"/>	> 1000 to 3000 lbs/day	3	15
	<input type="checkbox"/>	> 3000 lbs/day	4	20

Code Checked:   3  

Points Scored:   15  

B. Total Suspended Solids (TSS)

Permit Limits: (check one)	<input type="checkbox"/>		Code	Points
	<input type="checkbox"/>	< 100 lbs/day	1	0
	<input checked="" type="checkbox"/>	100 to 1000 lbs/day	2	5
	<input type="checkbox"/>	> 1000 to 5000 lbs/day	3	15
	<input type="checkbox"/>	> 5000 lbs/day	4	20

Code Checked:   2  

Points Scored:   5  

C. Nitrogen Pollutant: (check one)     Ammonia     Other: \_\_\_\_\_

Permit Limits: (check one)	<input type="checkbox"/>	Nitrogen Equivalent	Code	Points
	<input type="checkbox"/>	< 300 lbs/day	1	0
	<input type="checkbox"/>	300 to 1000 lbs/day	2	5
	<input type="checkbox"/>	> 1000 to 3000 lbs/day	3	15
	<input type="checkbox"/>	> 3000 lbs/day	4	20

Code Checked:   1  

Points Scored:   0  

**Total Points Factor 3:   20**

**FACTOR 4: Public Health Impact**

Is there a public drinking water supply located within 50 miles downstream of the effluent discharge (this includes any body of water to which the receiving water is a tributary)? A public drinking water supply may include infiltration galleries, or other methods of conveyance that ultimately get water from the above referenced supply.

YES (If yes, check toxicity potential number below)

NO (If no, go to Factor 5)

Determine the *human health* toxicity potential from Appendix A. Use the same SIC code and subcategory reference as in Factor 1. (Be sure to use the human health toxicity group column  check one below)

Toxicity Group	Code	Points	Toxicity Group	Code	Points	Toxicity Group	Code	Points
<input type="checkbox"/> No process waste streams	0	0	<input type="checkbox"/> 3.	3	0	<input type="checkbox"/> 7.	7	15
<input type="checkbox"/> 1.	1	0	<input type="checkbox"/> 4.	4	0	<input type="checkbox"/> 8.	8	20
<input type="checkbox"/> 2.	2	0	<input type="checkbox"/> 5.	5	5	<input type="checkbox"/> 9.	9	25
			<input type="checkbox"/> 6.	6	10	<input type="checkbox"/> 10.	10	30

Code Number Checked:   0   NA

**Total Points Factor 4:   0**

**FACTOR 5: Water Quality Factors**

NPDES NO VA0076015

A. *Is (or will) one or more of the effluent discharge limits based on water quality factors of the receiving stream (rather than technology-based federal effluent guidelines, or technology-based state effluent guidelines), or has a wasteload allocation been assigned to the discharge:*

<input checked="" type="checkbox"/>	Yes	Code 1	Points 10
<input type="checkbox"/>	No	2	0

B. *Is the receiving water in compliance with applicable water quality standards for pollutants that are water quality limited in the permit?*

<input checked="" type="checkbox"/>	Yes	Code 1	Points 0
<input type="checkbox"/>	No	2	5

C. *Does the effluent discharged from this facility exhibit the reasonable potential to violate water quality standards due to whole effluent toxicity?*

<input checked="" type="checkbox"/>	Yes	Code 1	Points 10
<input type="checkbox"/>	No	2	0

Code Number Checked: A 1 B 1 C 1

**Points Factor 5:** A 10 + B 0 + C 10 = 20 TOTAL

**FACTOR 6: Proximity to Near Coastal Waters**

A. *Base Score: Enter flow code here (from Factor 2): \_\_\_\_\_ Enter the multiplication factor that corresponds to the flow code: \_\_\_\_\_*

Check appropriate facility HPRI Code (from PCS):

HPRI#	Code	HPRI Score	Flow Code	Multiplication Factor	
<input type="checkbox"/>	1	1	20	11, 31, or 41	0.00
<input type="checkbox"/>	2	2	0	12, 32, or 42	0.05
<input type="checkbox"/>	3	3	30	13, 33, or 43	0.10
<input checked="" type="checkbox"/>	4	4	0	14 or 34	0.15
<input type="checkbox"/>	5	5	20	21 or 51	0.10
				22 or 52	0.30
				23 or 53	0.60
				24	1.00

HPRI code checked: 4

Base Score: (HPRI Score) 0 X (Multiplication Factor)     = 0 (TOTAL POINTS)

B. *Additional Points*  *NEP Program*  
*For a facility that has an HPRI code of 3, does the facility discharge to one of the estuaries enrolled in the National Estuary Protection (NEP) program (see instructions) or the Chesapeake Bay?*

<input type="checkbox"/>	Yes	Code 1	Points 10
<input type="checkbox"/>	No	2	0

C. *Additional Points*  *Great Lakes Area of Concern*  
*For a facility that has an HPRI code of 5, does the facility discharge any of the pollutants of concern into one of the Great Lakes' 31 areas of concern (see Instructions)*

<input type="checkbox"/>	Yes	Code 1	Points 10
<input type="checkbox"/>	No	2	0

Code Number Checked: A     B     C    

**Points Factor 6:** A     + B     + C     = 0 TOTAL

**SCORE SUMMARY**

NPDES NO. VA0076015

Factor	Description	Total Points
1	Toxic Pollutant Potential	<u>45</u>
2	Flows/Streamflow Volume	<u>      </u>
3	Conventional Pollutants	<u>20</u>
4	Public Health Impacts	<u>      </u>
5	Water Quality Factors	<u>20</u>
6	Proximity to Near Coastal Waters	<u>      </u>
TOTAL (Factors 1 through 6)		<u>85</u>

S1. Is the total score equal to or greater than 80?  Yes (Facility is a major)  No

S2. If the answer to the above questions is no, would you like this facility to be discretionary major?

No

Yes (Add 500 points to the above score and provide reason below:

Reason:

NEW SCORE: 85

OLD SCORE: 85

Lewis J. Pillis  
Permit Reviewer's Name

( 540 ) 562-6789  
Phone Number

July 23, 2018  
Date

ROCKY MOUNT QUADRANGLE  
 VIRGINIA—FRANKLIN CO.  
 7.5 MINUTE SERIES (TOPOGRAPHIC)


5058 III SE  
 (REDWOOD)

597 1 590 000 FEET

REDWOOD 4.6 MI.

2.3 MI. TO U.S. 220

79°52'30"  
 37°00"




OLD OFFLINE  
 ROCKY MT STP (DISCHARGE)  
 PGG - 57.72  
 36°59'21"  
 79°52'34"  
 56.6 RM

RONILE, INC. (MARTIN PROCESSING)  
 IND. NO. DISCHARGE  
 36°59'05"  
 79°52'36"  
 Ronile  
 DISCHARGE 002  
 PGG - 57.5p  
 36°58'57"  
 79°52'55"

ROAD  
 STREET STATION  
 PGG 57.85  
 should be  
 PGG-57.92

37 50 27  
 79 53 34

SCALE 1:24 000




CONTOUR INTERVAL 20 FEET  
 NATIONAL GEODETIC VERTICAL DATUM OF 1929

THIS MAP COMPLIES WITH NATIONAL MAP ACCURACY STANDARDS  
 FOR SALE BY U. S. GEOLOGICAL SURVEY, RESTON, VIRGINIA 22092  
 AND VIRGINIA DIVISION OF MINERAL RESOURCES, CHARLOTTEVILLE, VIRGINIA 22903  
 A FOLDER DESCRIBING TOPOGRAPHIC MAPS AND SYMBOLS IS AVAILABLE ON REQUEST



6-4-13  
W.T.

- NOTES:  
1) DIST  
2) DIST  
3) STOR  
TO C




RONIVE, INC.  
ROCKY MOUNT, VA  
STORMWATER DRAINAGE MAP

~ = HIGH ELEVATION AREA  
MARKING SEPARATION OF  
DRAINAGE SECTIONS

006 15' ROOF STORM DRAIN 007

Title:	
Site:	
Client:	
Modified by:	
Drawing #:	
EARTH	



**FLOW DIAGRAM FOR FIBER DYEING PROCESS**

RONILE, INC.  
ROCKY MOUNT, VIRGINIA

AECOM TECHNICAL SERVICES INC.

COMM. NO. 60280437

DATE: FEBRUARY 2013



Ronile Inc., MSDSs reviewed:

110-10003	ACID YELLOW 4NGL 200% Monoazo	109092	ACID YELLOW 4NGL 200% >50% CAS# 69762-08-9	Color sources, Inc.	10 lb
120-10018	LEVELER PPL	127670	LEVELER PPL	Piedmont Chemical Ind Inc	10
120-10506	VERSATINT SUPRA GREEN	123900	VERSATINT SUPRA GREEN	Milliken & Company	15
110-10069	ACID RED 2G Monoazo dye	109092	ACID RED 2G 12270-02-9	Color sources, Inc.	30
110-10034	ASTRAZON BRILL RED 4GN 200 (basic red 14, a methine dyestuff)	110085	DORACREL BRIL RED X4GS 200% CAS# 72208-31-0	M Dohmen USA, Inc	35
120-10028	CARRIER NOC	127670	CARRIER NOC	Piedmont Chemical Ind Inc	50
120-10503	MUANOX CONC	127490	MUANOX CONC	Peachstate Labs Inc	60
110-10386	ACID RED 2B	111840	DYE O NYL RED 2B  CAS# 61931-22-4	Dye-O-Chem, American Inc	65
110-10425	ACRYLIC YELLOW X8G	110085	Doracryl yellow X8GLS 200% 25-50% CAS# 25717-55-9	M Dohmen USA, Inc	65
<b>H400, H410*</b>	Aquatic Acute1 & Chronic 1 Basic dye				
110-10026	ACID ORANGE 3G 200% AKA Acid orange 156	113200	FOURACID ORANGE 3G 200 contains Sodium tripolyphosphate	Fibro Chem Inc	80
110-10085	TELON BLACK BLD 100%	109092	ACID BLACK 2S-LD	ColorSources, Inc.	100
110-10427	DORACRYL FAVINE X10G 600% a methine dyestuff	110085	DORACRYL FAVINE X10G 600%	M Dohmen USA, Inc	110
120-10389	SODIUM HYDROSULFITE WRM	128900	PRES CLEAR WRM	Prescott Chemical Inc	125
110-10387	ACID BLUE BRL 200%	108500	TECTILON BLUE M-AR	Huntsman International, LLC	160
110-10033	ASTRAZON BLUE BG 200% Basic dye	110085	DORACRYL BLUEGREEN X5GS 200 CAS#33203-82-6	M Dohmen USA, Inc	175
110-10364	PREMET BORDEAUX R CI acid red 182	120255	KEMALAN BORDEAUX K-RL CAS# 5802-43-5	Jaychem LLC	190

110-10366	ACRYLIC RED GRL	110085	DORACRYL RED XGRSL 200%	M Dohmen USA, Inc	210
<b>H412*</b>	Aquatic Chronic 3 Azo dyestuff		>25% CAS# 93804-07-0		
110-10035	ASTRAZON RED VLT 3RNO1	110085	DORACRYL BRILL RED XBG	M Dohmen USA, Inc	220
<b>H410*</b>	Basic dye		60-70% CAS# 6359-45-1		
110-10363	PREMET YELLOW LNW 250%	113200	FOURACID YELLOW NW 250	Fibro Chem Inc	230
	<b>Metal complex dye contains cobalt</b>				
110-10032	ACRYLIC BLUE FGGL 300%	110085	DORACRYL BLUE X3GLS 300	M Dohmen USA, Inc	425
	Monoazo dyestuff		CAS# 12270-13-2	Basic blue 41 (zinc free)	
110-10054	PREMET BLACK BGL 200%	111840	DYE-O-LAN BLACK BGL 200%	Dye-O-Chem, American Inc	450
	Acid black 1, CI acid black 107		CAS# 12218-96-1		
120-10401	ASTRAGAL PAN-02	104255	ASTRAGAL PAN-02	StarChem LLC	450
				X	
110-10021					
<b>H400, H410*</b>	ACRYLIC GOLDEN YEL GL 200	110085	DORACRYL GOLD YELLOW XGFLS	M Dohmen USA, Inc	530
	Aquatic Acute 1 &Chronic 1 – Basic		200 45-55% CAS# 38936-35-5		
120-10016	Buffer 5 Tote	127670	Buffer 5 Tote	Piedmont Chemical Ind Inc	495
120-10339	PRO GUM 493/Aqualon 49323 GUAR	113200	GALACTASOL 20H5FD GUAR	Fibro Chem Inc	750
120-10036	WETTER D-90	127670	WETTER D-90	Piedmont Chemical Ind Inc	950
120-10060	BUFFER R	127670	BUFFER R	Piedmont Chemical Ind Inc	950
120-10493	SYNTHASIL SW 216	127670	SYNTHASIL SW 216	Piedmont Chemical Ind Inc	1,025
120-10051	NOVOC A-80	127490	NOVOC A-80	Peachstate Labs Inc	1,100
120-10005	POMOCO 1014T DRUM	127670	POMOCO 1014T	Piedmont Chemical Ind Inc	1,350
120-10047	FOAM PRESS 50	128900	FOAM PRESS 50	Prescott Chemical Inc	1,700
120-10019	FORMAC 50% BULK		N/A	#N/A	1,793
120-10080	POLYWET 750 DE		N/A	#N/A	3,227

120-10502	POMOLUBE TXJ-22	127670	POMOLUBE TXJ-22	Piedmont Chemical Ind Inc	4,050
120-10048	ACETIC ACID 56% TOTE	105902	ACETIC ACID 56%	Brenntag Southeast	4,780
120-10004	POMOSOFT 540	127670	POMOSOFT 540	Piedmont Chemical Ind Inc	5,250
120-10050	NICCA-RESIST SB-4	124636	NICCARESIST SB-4	Nicca USA Inc X	5,685

Environmental hazards from Globally Harmonized System of Classification and Labelling of Chemicals (GHS);  
not adopted by all dye manufacturers:

H400: Very toxic to aquatic life

H401: Toxic to aquatic life

H402: Harmful to aquatic life

**H410: Very toxic to aquatic life with long-lasting effects (Aquatic Chronic)**

H411: Toxic to aquatic life with long-lasting effects

H412: Harmful to aquatic life with long-lasting effects (Aquatic Chronic)

H413: May cause long-lasting harmful effects to aquatic life

Ronile Inc  
VA0076015

Outfall 001

	FLOW, MGD			pH, SU		BOD5, mg/L		COD, mg/L	TSS, mg/L		Zn, ug/L	Cu, ug/L	Cr, mg/L	Phenolics, mg/L		Phenolics, Kg/D		Color, ADMI	
	Mo. Ave	An. Ave.	Max	Min	Max	ave	max		ave	max				ave	max	ave	max		
limit=>				6.0	9.0	NL	NL	NL	NL	NL	140	20	NL	NL	NL	0.97	1.9	499	
2015	5	0.09	0.117	7.34	7.98	<QL	<QL	80	6.1	8	70	<QL	<QL	0.03	0.04	0.01	0.02	124	
	6	0.087	0.114	7	8.26	1.7	5	111	7.3	9	62	<QL	<QL	0.03	0.03	0.01	0.01	243	
	7	0.076	0.107	7.1	7.77	<QL	<QL	81	9	16	77	<QL	<QL	0.02	0.03	0.01	0.01	274	
	8	0.085	0.119	7.14	8.12	1.8	5.5	118	9	15	42	<QL	0.1	0.02	0.02	0.01	0.01	290	
	9	0.105	0.128	6.72	7.95	<QL	<QL	84	9	14	70	<QL	<QL	0.01	0.01	0.01	0.01	248	
	10	0.105	0.129	7.07	<b>8.58</b>	<QL	<QL	55	11	13	45	<QL	<QL	0.01	0.02	0	0.01	148	
	11	0.097	0.133	7.14	7.84	2.9	6.5	55	12	15	56	<QL	<QL	<QL	<QL	<QL	<QL	222	
	12	0.097	0.092	0.126	7.11	7.84	1.5	6	55	10	12	110	<QL	<QL	0.012	0.014	0.01	0.01	182
2016	1	0.09	0.118	7.27	7.95	3.6	7.7	66	14	20	89	<QL	<QL	0.03	0.05	0.01	0.02	138	
	2	0.148	0.189	7.28	8.26	<QL	<QL	77	8	23	110	<QL	<QL	0.01	0.01	0.01	0.01	104	
	3	<b>0.158</b>	<b>0.2</b>	6.72	7.98	<QL	<QL	63	11	20	89	<QL	<QL	0.03	0.06	0.01	0.02	136	
	4	0.15	0.186	6.86	7.42	<QL	<QL	62	6	7	81	<QL	<QL	0.02	0.03	0.01	0.01	135	
	5	0.104	0.137	6.86	7.42	<QL	<QL	54	6	8	50	<QL	<QL	0.01	0.02	0.01	0.01	165	
	6	0.095	0.118	6.69	7.42	<QL	<QL	56	10	18	57	<QL	<QL	0.02	0.02	0.01	0.01	248	
	7	0.083	0.11	6.44	7.7	<QL	<QL	73	11	19	44	<QL	<QL	0.04	0.04	0.01	0.02	249	
	8	0.098	0.127	6.58	7.42	<QL	<QL	72	9	13	48	<QL	<QL	0.03	0.03	0.01	0.02	262	
	9	0.103	0.126	6.71	7.58	1.9	5.7	146	6	7	43	<QL	<QL	0.03	0.05	0.01	0.02	189	
	10	0.105	0.125	6.83	7.33	<QL	<QL	58	5	8	73	<QL	<QL	0.02	0.02	0.01	0.01	163	
	11	0.115	0.132	7.23	7.56	<QL	<QL	58	3	4	37	<QL	<QL	0.04	0.04	0.02	0.02	150	
	12	0.12	0.114	0.153	7.08	7.84	3	6	78	4	5	61	<QL	<QL	0.06	0.12	0.03	0.06	111
2017	1	0.106	0.144	7	7.7	1.7	5.2	119	5	7	95	<QL	<QL	0.07	0.1	0.03	0.05	123	
	2	0.1	0.129	7	7.28	<QL	<QL	84	5	7	41	<QL	<QL	0.07	0.09	0.03	0.04	124	
	3	0.107	0.133	6.44	7.48	<QL	<QL	75	3	8	47	<QL	0.01	0.01	0.02	0.01	0.01	131	
	4	0.108	0.14	6.77	7.42	<QL	<QL	62	3	4	45	<QL	<QL	0.025	0.026	0.012	0.013	138	
	5	0.101	0.135	6.8	7.56	<QL	<QL	67	3	3	52	<QL	0.02	<QL	<QL	<QL	<QL	151	
	6	0.097	0.135	6.86	7.56	<QL	<QL	68	4	7	32	<QL	<QL	0.02	0.02	0.01	0.01	175	
	7	0.102	0.128	6.86	7.32	<QL	<QL	70	3	3	45	<QL	<QL	0.01	0.01	0.01	0.01	218	
	8	0.103	0.14	6.72	7.42	<QL	<QL	70	2	2	65	<QL	<QL	<QL	<QL	<QL	<QL	212	
	9	0.118	0.14	6.58	7.42	<QL	<QL	62	6	13	51	<QL	<QL	0.01	0.01	0	0.01	188	
	10	0.114	0.139	6.72	7.28	<QL	<QL	59	3	3	52	<QL	<QL	<QL	<QL	<QL	<QL	176	
	11	0.118	0.152	6.72	7.56	<QL	<QL	45	2	3	82	<QL	<QL	<QL	<QL	<QL	<QL	222	
	12	0.087	0.105	0.134	6.72	7.56	<QL	<QL	70	4	8	74	<QL	<QL	0.01	0.02	0.01	0.01	154
2018	1	0.095	0.147	6.78	7.6	5	25.1	131	4	12	47	<QL	<QL	<QL	<QL	<QL	<QL	160	
	2	0.115	0.146	6.86	7.44	<QL	<QL	113	3	5	42	<QL	<QL	0.007	0.022	0.004	0.011	188	
	3	0.119	0.145	6.86	7.62	<QL	<QL	64	2	3	68	<QL	0.01	<QL	0.01	<QL	0.01	134	
	4	0.111	0.143	6.86	7.47	<QL	<QL	70	4	6	21	<QL	<QL	0.022	0.032	0.011	0.017	170	
		0.106	0.2	6.44	8.58	results show toxicity in BOD test					60.4								290 max
		LT ave	max	min	max						ave							179 ave	

Note: O&G and total sulfides were <QL for all months

Ronile Inc  
VA0076015


Outfall 001

Evaluation to see if toxicity is evident in BOD tests.

		BOD5, mg/L		BOD <QL=2	COD, mg/L	COD/BODave ratio	COD/BODmax ratio	Zn, ug/L	TUa	
		ave	max							
2015	5	<QL	<QL	2	80		40	62		
	6	1.7	5	5	111	65	22	77	<1.0	
	7	<QL	<QL	2	81		41	42		
	8	1.8	5.5	5.5	118	66	21	70		
	9	<QL	<QL	2	84		42	45	<1.00	
	10	<QL	<QL	2	55		28	56		
	11	2.9	6.5	6.5	55	19	8	110		
	12	1.5	6	6	55	37	9	89	<1.0	
	2016	1	3.6	7.7	7.7	66	18	9	110	
		2	<QL	<QL	2	77		39	89	
		3	<QL	<QL	2	63		32	81	<1.0
		4	<QL	<QL	2	62		31	50	
5		<QL	<QL	2	54		27	57		
6		<QL	<QL	2	56		28	44	<1.0	
7		<QL	<QL	2	73		37	48		
8		<QL	<QL	2	72		36	43		
9		1.9	5.7	5.7	146	77	26	73	<1.0	
10		<QL	<QL	2	58		29	37		
11		<QL	<QL	2	58		29	61		
12		3	6	6	78	26	13	95	<1.0	
2017	1	1.7	5.2	5.2	119	70	23	41		
	2	<QL	<QL	2	84		42	47		
	3	<QL	<QL	2	75		38	45	1.23	
	4	<QL	<QL	2	62		31	52		
	5	<QL	<QL	2	67		34	32		
	6	<QL	<QL	2	68		34	45	<1.0	
	7	<QL	<QL	2	70		35	65		
	8	<QL	<QL	2	70		35	51		
	9	<QL	<QL	2	62		31	52	1.41	
	10	<QL	<QL	2	59		30	82		
	11	<QL	<QL	2	45		23	74		
	12	<QL	<QL	2	70		35	47	1.42	
2018	1	5	25.1	25.1	131	26	5	42		
	2	<QL	<QL	2	113		57	68		
	3	<QL	<QL	2	64		32	21	3.27	
	4	<QL	<QL	2	70		35	42		

26 to 77  
ave = 45      5 to 57  
ave = 30

### Annual Sulfate Trend - Ronile Lagoon Monitoring Wells





MEMORANDUM

DEPARTMENT OF ENVIRONMENTAL QUALITY  
*Blue Ridge Regional Office*

3019 Peters Creek Road

Roanoke, VA 24019

SUBJECT: Site Visit, Rōnile, Inc., VPDES Permit No. VA0076015

TO: Kip Foster

FROM: Lewis Pillis

DATE: July 3, 2018

COPIES: file

I visited the subject facility on Monday, July 2nd. Wade Thompson, Environmental Manager, accompanied me on a tour of the outside operations. The WWTP (AKA water plant) operates 5 days/week or less even though the manufacturing operates every day. The River at outfall 001 was viewed from the catwalk, but effluent was not visible. The aeration basin was nearly full and the curtain that separates the basin was torn and Wade stated that a quote for a replacement had been obtained and a new curtain would be replaced in future. A small amount of sludge was on a drying bed.

Outfall 004, stormwater from the paved area around the wastewater plant enters the River immediately downstream of outfall 001. Monitoring well 4 is just on the upstream side of the path to 001. The site map shows the relative locations, but not their proximity to each other.

Old equipment was being stored behind the warehouse. This area drains through outfall 003 to the vegetated utility easement.

A concrete unloading ramp for sawdust is under construction. Sawdust is used as fuel in the boiler. Previously, sawdust was used as a ramp to the unloading conveyor. Sawdust washes to a low place in the parking lot, and runs into the easement area via outfall 009. There is screening in place to catch some of the sawdust. Sawdust has passed through or around the screen and accumulated at the fence line, so that there is a spongy layer of sawdust at this point. Sawdust needs to be removed from in front of the screen and fence. It was reported that there is rip rap beyond the fence, but it could not be seen due to vegetation growing on the fence. Once the ramp is built, less sawdust will wash to the outfall.

Stormwater falling just southwest of the sawdust unloading area flows to outfall 007 via a half acre grassy area. A couple of spots could be seen where solids had settled in the grass. Concrete at the fence appeared to be breaking up and was in need of repair. Outfall 005 is in the southern corner of facility at the end of a ditch and is noted incorrectly on the site map at the upper end of the ditch.

Production at the facility was discussed and it was noted that production has gradually changed, in the past 4 to 5 years, from the use of acid dyes, which could be recycled, to acrylic or basic dyes, which cannot be recycled. There had also been an increase in the amount of chemicals used in dyeing. Wool is not being dyed currently and is not being considered. It was stated that the Technical Director researched toxicity of all chemicals prior to use, but that ecological information (i.e. aquatic toxicity) was not always available. The writer shared that some SDSs provided to DEQ contain GHS hazard

codes indicating they are chronically toxic to aquatic organisms, but that many SDSs had no information at all about ecological affects.

It was stated that there had been a large increase (10x) in the use of Pres Clear WRM over the same time period. The SDS indicates that this is stabilized sodium hydrosulfite, CAS #7775-14-6 (AKA sodium dithionite) and no ecological information is provided. It was hypothesized that this chemical along with Nicca Resist may have had the effect on the aeration basin of releasing dye and zinc from sludge.

# APPENDIX B

## RECEIVING WATERS INFORMATION

Flow Frequency Memo  
STOReT Data

MEMORANDUM

DEPARTMENT OF ENVIRONMENTAL QUALITY  
*West Central Regional Office*

3019 Peters Creek Road

Roanoke, VA 24019

SUBJECT: Flow Frequency Determination, Ronile, Inc. WWTP  
VPDES Permit No. VA0076015

TO: File

FROM: Lewis Pillis

DATE: April 29, 2013

COPIES:

Critical flows for the gages used in preparing the referenced permit have changed since development of the last permit. In 2011, USGS calculated low flows from the gages previously used. These gage flows were used to find resulting critical flows at the Ronile facility and then averaged. The two gages used previously are:

Blackwater River gage # 02056900 at Rocky Mount  
Pigg River gage # 02058400 near Sandy Level

The Surface Water Investigations Office in Charlottesville performed 14 site specific flow measurements on the Pigg River, near Ronile at Latitude 36 59'02", Longitude 79 52'52", NAD 83, between 1993 and 2005. Mean daily flows, on the same days, at the gages above were found in the USGS web-interface. The same correlation, using standard Agency regression analysis in 2008 was maintained and new critical flows determined at Ronile were calculated by inserting each gage's critical flows into the relationship [regression equation] and then averaged. Regression curves are shown on the following pages.


Critical flows at the Ronile outfall 001 on the Pigg River are determined to be:

	<u>cfs in 2008; cfs in 2011</u>		<u>MGD in 2008; MGD in 2011</u>	
1Q10	8.96	9.42	5.79	6.1
7Q10	10.0	10.5	6.49	6.8
30Q5	18.1	18.4	11.7	11.9
30Q10	14.2	14.8	9.2	9.5
HF 1Q10	25.2	*	16.3	*
HF 7Q10	28.1	*	18.1	*
Harmonic Mean	41.9	*	27.1	*

High flow months are Jan – May

\* Flow not recalculated by USGS

Pigg River above Ronile STP, at Rocky Mount, VA #02057650  
vs Blackwater River near Rocky Mount, VA #02056900



**Flow Data (cfs)**

Date	Blackwatr	Pigg_RM
9/1/1993	39	39
6/22/1994	57	47.2
11/9/1994	50	42.2
11/19/1996	128	86.3
5/22/1997	94	74.4
6/24/1997	84	58.7
9/17/1997	35	29.4
8/17/1999	5.9	7.06
7/8/2004	70	41.6
7/29/2004	59	43.3
8/26/2004	42	38.8
9/21/2004	128	59.1
11/1/2004	103	54.6
12/8/2004	182	78.2

**SUMMARY OUTPUT**

<i>Regression Statistics</i>	
Multiple R	0.985115
R Square	0.970452
Adjusted R Square	0.965527
Standard Error	4.66325
Observations	14


**Flow Frequencies (cfs)**

Blackwatr		Pigg_RM
8.4	1Q10	10.898
9.8	7Q10	12.152
22	30Q5	21.511
32	HF 1Q10	28.027
38	HF 7Q10	31.643
61	HM	44.202
16	30Q10	17.179
115 mi2	DA	68.8 mi2
	Jan-May	
85	4/25/2008	55.872

2011 USGS flow frequencies (cfs)

Blackwatr		Pigg_RM
8.84	1Q10	11.299
10.3	7Q10	12.587
22.1	30Q5	21.580
32	HF 1Q10	28.027
38	HF 7Q10	31.643
61	HM	44.202
17	30Q10	17.930
115 mi2	DA	68.8 mi2
	Jan-May	

Pigg River above Ronile STP, at Rocky Mount, VA #02057650  
vs Pigg River near Sandy Level, VA #02058400



**Flow Data (cfs)**

Date	Pigg SL	Pigg RM
9/1/1993	143	39
6/22/1994	190	47.2
11/9/1994	182	42.2
11/19/1996	383	86.3
5/22/1997	352	74.4
6/24/1997	272	58.7
9/17/1997	170	29.4
8/17/1999	57	7.06
7/8/2004	236	41.6
7/29/2004	337	43.3
8/26/2004	217	38.8
9/21/2004	318	59.1
11/1/2004	280	54.6
12/8/2004	462	78.2

**SUMMARY OUTPUT**

Regression Statistics	
Multiple R	0.977322
R Square	0.955159
Adjusted R Square	0.947686
Standard Error	5.744595
Observations	8

**Flow Frequencies (cfs)**

Pigg SL	Pigg RM	
42	1Q10	7.031
47	7Q10	7.937
83	30Q5	14.646
123	HF 1Q10	22.374
134	HF 7Q10	24.537
209	HM	39.609
65	30Q10	11.255
350 mi2	DA	68.8 mi2
	Jan-May	
353	4/25/2008	69.665

date cross section was measured

2008 FLOWS:

Blackwater	Pigg RM	Ave, cfs	Ave, MGD
	10.898	8.964798	5.79
	12.152	10.04438	6.49
	21.511	18.07848	11.68
	28.027	25.20074	16.29
	31.643	28.09038	18.15
	44.202	41.90528	27.08
	17.179	14.21688	9.19

River/Diffuser measurements made on 4/25/8 by Roger McBride of Ronile:

flow at Pigg River gage was 353 cfs on 4/25/8  
flow at Blackwater River gage was 85 cfs on 4/25/8

Average of calculated flows at Ronile =  $(86.659+64.559)/2$   
75.609 cfs  
48.8661 MGD

**2011 USGS Flow Frequencies (cfs)**

Pigg SL	Pigg RM	
44.8	1Q10	7.537
49.9	7Q10	8.466
86.4	30Q5	15.293
123	HF 1Q10	22.374
134	HF 7Q10	24.537
209	HM	39.609
66.7	30Q10	11.573
350 mi2	DA	68.8 mi2
	Jan-May	

Blackwater/

Pigg RM	Ave, cfs	Ave, MGD	% change
11.2986	9.417981	6.09	5.06%
12.58652	10.5261	6.80	4.80%
21.57992	18.43666	11.92	1.98%
28.02703	25.20074	16.29	0.00%
31.64341	28.09038	18.15	0.00%
44.20181	41.90528	27.08	0.00%
17.93012	14.75132	9.53	3.76%

2011 USGS gage flows shown in italics



Pigg River Data Upstream of Ronile

Station ID 4APGG057.85

Collection Date Time	Temp Celcius	Field pH	Date	Temp C	Date	Field pH
02/27/2007 11:30	6.1	7.4	1 08/14/2007	23.5	04/05/2007	7.5
04/05/2007 12:00	12.5	7.5	2 08/07/2008	22.7	02/27/2007	7.4
06/05/2007 12:00	19.2	5.9	3 06/02/2008	21.6	02/05/2008	7.2
08/14/2007 14:00	23.5	6.1	4 06/05/2007	19.2	10/09/2008	7.2
10/02/2007 12:00	15.2	6.1	5 10/09/2008	16.8	08/07/2008	7.1
12/05/2007 12:00	3.4	6.6	6 10/02/2007	15.2	12/16/2008	7
02/05/2008 12:00	9.3	7.2	7 04/05/2007	12.5	12/05/2007	6.6
04/07/2008 12:30	10.4	6.6	8 04/07/2008	10.4	04/07/2008	6.6
06/02/2008 12:30	21.6	6.5	9 02/05/2008	9.3	06/02/2008	6.5
08/07/2008 13:00	22.7	7.1	10 12/16/2008	8.1	08/14/2007	6.1
10/09/2008 14:00	16.8	7.2	11 02/27/2007	6.1	10/02/2007	6.1
12/16/2008 11:00	8.1	7	12 12/05/2007	3.4	06/05/2007	5.9

PIGG RIVER DATA

Station 4APGG057.84 upstream of Ronile

Collection\_Date\_Time = 2002-06-25 12:15:00.0

Value

ALUMINUM AL,DISS UG/L	10.6 --	
ANTIMONY SB,DISS UG/L	0.1	Material Analyzed for, but not detected. Value stored is the limit of detection.
ARSENIC AS,DISS UG/L	0.28 --	
BARIUM BA,DISS UG/L	19 --	
BERYLIUM BE,DISS UG/L	0.1	Material Analyzed for, but not detected. Value stored is the limit of detection.
CADMIUM CD,DISS UG/L	0.1	Material Analyzed for, but not detected. Value stored is the limit of detection.
CALCIUM CA,DISS MG/L	9.2 --	
CHROMIUM CR,DISS UG/L	0.12 --	
COPPER CU,DISS UG/L	0.68 --	
IRON FE,DISS UG/L	144 --	
LEAD PB,DISS UG/L	0.1	Material Analyzed for, but not detected. Value stored is the limit of detection.
MANGNESE MN,DISS UG/L	28 --	
MGNSIUM MG,DISS MG/L	4.8 --	
NICKEL NI,DISS UG/L	0.38 --	
SELENIUM SE,DISS UG/L	0.5	Material Analyzed for, but not detected. Value stored is the limit of detection.
SILVER AG,DISS UG/L	0.1	Material Analyzed for, but not detected. Value stored is the limit of detection.
THALLIUM TL,DISS UG/L	0.2	Material Analyzed for, but not detected. Value stored is the limit of detection.
ZINC ZN,DISS UG/L	2.55 --	

# STORET Stream data

Station 4APGG068.49

Date Time	Depth	Temp Celsius	Field Ph	Parm Name	Value
7/26/2001	0.3	26.1	7.7	HARDNESS, TOTAL (MG/L AS CACO3)	30.9
9/4/2001	0.3	21	8	HARDNESS, TOTAL (MG/L AS CACO3)	23.4
11/29/2001	0.3	11.7	8	HARDNESS, TOTAL (MG/L AS CACO3)	27.7
1/10/2002	0.3	7	7.4	HARDNESS, TOTAL (MG/L AS CACO3)	17.5
3/14/2002	0.3	8.3	7.1	HARDNESS, TOTAL (MG/L AS CACO3)	23.9
5/15/2002	0.3	17.5	7.93	HARDNESS, TOTAL (MG/L AS CACO3)	31
7/16/2002	0.3	21.6	7.9	HARDNESS, TOTAL (MG/L AS CACO3)	38.3
9/19/2002	0.3	20.5	8.03	HARDNESS, TOTAL (MG/L AS CACO3)	36.7
11/18/2002	0.3	8.6	7.51	HARDNESS, TOTAL (MG/L AS CACO3)	34.5
2/3/2003	0.3	4.7	7.8	HARDNESS, TOTAL (MG/L AS CACO3)	29.1
3/11/2003	0.3	5.6	7.8	HARDNESS, TOTAL (MG/L AS CACO3)	33.2
5/27/2003	0.3	14.8	7.42	HARDNESS, TOTAL (MG/L AS CACO3)	31.9

# APPENDIX C

## PERMIT LIMIT DEVELOPMENT

Waste Load Allocation Spreadsheet  
STATS printouts

Ronile Inc. VA0076015

Federal Effluent Guidelines - 40 CFR Part 410, Subpart G, NSPS

Parameter	Effluent Guidelines Average (kg/Kkg)	Effluent Guidelines Maximum (kg/Kkg)	Effluent Limit Average (kg/day)	Effluent Limit' Maximum (kg/day)	Equivalent concentration at max 30 day ave flow & average loading limit (mg/L)	Equivalent concentration at max 30 day ave flow & maximum loading limit (mg/L)
BOD <sub>5</sub>	1.9	3.6	19.38	36.72		
COD	21.9	33.9	223.38	345.78		
TSS	4.4	9.8	44.88	99.96		
Sulfide	0.12	0.24	1.22	2.45	2.0	4.1
Phenols	0.06	0.12	0.61	1.22	1.0	2.0
Total Chromium	0.06	0.12	0.61	1.22	1.0	2.0
pH	6.0 - 9.0 at all times					

Notes:

Production rate from 2017 form 2C

Average Daily Production (kkg) = 10.2

MEMORANDUM

DEPARTMENT OF ENVIRONMENTAL QUALITY  
*West Central Regional Office*

3019 Peters Creek Road

Roanoke, VA 24019

SUBJECT: CORMIX Model Results, Ronile, Inc., Rocky Mount, Franklin County  
VPDES Permit Number: VA0076015

TO: Kip Foster

FROM: Lewis Pillis 

DATE: June 9, 2008

COPIES: file

Ronile recently replaced their diffuser with a different arrangement. CORMIX modeling was used to determine whether estimated dilution using the new port arrangement will change. The Technical Support Document for Water Quality-based Toxics Control, EPA/505/2-90-001, March 1991, [TSD] is currently used by DEQ to evaluate mixing zones. Decision criteria from page 72 of the TSD are used to determine dilution in the zone of initial dilution [ZID], or acute mixing zone. In this case, the critical dimension to prevent acute affects to aquatic organisms, is 10% of the regulatory mixing zone in any direction, which calculates to 0.53 meters.

Ronile measured the diffuser and river depth on April 25, 2008. The River measured 39.3 ft wide with a maximum depth of 4.6 ft. Gage flows on this date were obtained. Using the same regression analysis as in flow frequency determination, the flow of the Pigg River at the outfall on that day was determined to be 75.61 cfs [48.9 MGD]. According to the USGS web site this is about average flow for April 25th. Based on these measurement, the cross sectional area of the river at the diffuser is estimated to be 105 ft<sup>2</sup>. The River bottom has an obtuse parabolic shape.

Since the diffuser at Ronile has two different sized ports, the average diffuser port effective diameter was determined by dividing the total diffuser port area by the number of ports and assuming a circular port shape. There are two 6 in<sup>2</sup> ports and three 18 in<sup>2</sup> ports for a total of 66 in<sup>2</sup>, or an average port area of 13.2 in<sup>2</sup>. The diameter of a 13.2 in<sup>2</sup> port would be 4.1 inches. This is used as the effective diameter [0.1041 meters].

Results from CORMIX runs at acute conditions, show that dilution at 0.53 meters downstream varies depending on the river width and depth used. An acute dilution of 7.0 resulted when the following inputs were used:

1Q10 = 5.8 MGD [0.223 m<sup>3</sup>/s]  
river width = 35 ft [10.67 m]  
local river depth = 3 ft [0.914 m]  
average river depth = 2.7 ft [0.823 m]  
height of diffuser off bottom = .2m  
river temp = 25C, effluent temp = 25.6C



Separate model runs at 7Q10 were used to estimate dilution under chronic conditions. Under chronic conditions, the critical factor is the maximum width of the plume which should not exceed half of the River's width. Dilution is evaluated when the "half-width" of the CORMIX plume is equal to  $35/2$  or 17.5 feet (5.33 meters). Dilution of 19.5:1 occurs when the 7Q10 = 6.5 MGD and the river dimensions are the same as above.

An attempt was made to calculate critical River dimensions using flow frequency and the measured River dimensions and known gage flow. Although, the calculated cross sectional area compares favorably with area calculated using the V-shape formula in ESC handbook p. V-133 of  $91.87 \text{ ft}^2$ , width or depth at low flows still cannot be estimated mathematically. Output from the CORMIX model depended more on River width and depth, than other model variables.

# CORMIX -- CORNELL MIXING ZONE EXPERT SYSTEM -- Version 3.00-3.20

SITE Name Ronite Date: \_\_\_\_\_  
 Design CASE \_\_\_\_\_ Prepared by: \_\_\_\_\_  
 DOS FILE NAME \_\_\_\_\_ (w/o extension)

**AMBIENT DATA:** Water body is bounded/unbounded  
 Water body depth .87-1.0 m If bounded: Width 7.6-9.1 m  
 Depth at discharge same m Appearance 1/2/3  
 If steady: Ambient flowrate .2541 m<sup>3</sup>/s or: Ambient velocity \_\_\_\_\_ m/s  
 If tidal: Tidal period \_\_\_\_\_ hr Max. tidal velocity \_\_\_\_\_ m/s  
 At time \_\_\_\_\_ hr before/at/after slack: Tidal velocity at this time \_\_\_\_\_ m/s  
 Manning's n 1035-0.045 .04 or: Darcy-Weisbach f \_\_\_\_\_  
 Wind speed \_\_\_\_\_ m/s  
**Density data:** UNITS: Density...kg/m<sup>3</sup> / Temperature...°C  
 Water body is fresh/salt water If fresh: Specify as density/temp. values  
 If uniform: Average density/temp. 23  
 If stratified: Density/temp. at surface \_\_\_\_\_  
 Stratification type A/B/C Density/temp. at bottom \_\_\_\_\_  
 If B/C: Pycnocline height \_\_\_\_\_ m If B/C: Density/temp. jump \_\_\_\_\_

**DISCHARGE DATA:** Specify geometry for CORMIX1 or 2 or 3

**SUBMERGED SINGLE PORT DISCHARGE -- CORMIX1**  
 Nearest bank is on left/right Distance to nearest bank 3.317 m  
 Vertical angle THETA \_\_\_\_\_ ° Horizontal angle SIGMA \_\_\_\_\_ °  
 Port diameter effective .1041 m or: Port area \_\_\_\_\_ m<sup>2</sup>  
 Port height .2 m


**SUBMERGED MULTIPORT DIFFUSER DISCHARGE -- CORMIX2**  
 Nearest bank is on left/right Distance to one endpoint 3.317 m  
 Diffuser length 1.5621 m to other endpoint 4.879 m  
 Total number of openings 5 Port height 0.2 m  
 Port diameter .1041 m with contraction ratio 1.0  
 Diffuser arrangement/type unidirectional / staged / alternating or vertical  
 Alignment angle GAMMA 90 ° Horizontal angle SIGMA 0 °  
 Vertical angle THETA 0 ° Relative orientation BETA 90 °

**BUOYANT SURFACE DISCHARGE -- CORMIX3**  
 Discharge located on left/right bank Configuration flush/protruding/co-flowing  
 Horizontal angle SIGMA \_\_\_\_\_ ° If protruding: Dist. from bank \_\_\_\_\_ m  
 Depth at discharge \_\_\_\_\_ m Bottom slope \_\_\_\_\_ °  
 If rectangular Width \_\_\_\_\_ m or: If circular Diameter \_\_\_\_\_ m  
 discharge channel: Depth \_\_\_\_\_ m pipe: Bottom invert depth \_\_\_\_\_ m

Effluent: Flow rate 0.00638 m<sup>3</sup>/s or: Effluent velocity \_\_\_\_\_ m/s  
 Effluent density \_\_\_\_\_ kg/m<sup>3</sup> or: Effluent temperature 25.6 °C  
 Heated discharge? yes/no If yes: Heat loss coefficient \_\_\_\_\_ W/m<sup>2</sup>,°C  
 Concentration units \_\_\_\_\_ Effluent concentration \_\_\_\_\_  
 Conservative substance? yes/no If no: Decay coefficient \_\_\_\_\_ /day

**MIXING ZONE DATA:**  
 Is effluent toxic? yes/no If yes: CMC \_\_\_\_\_ CCC \_\_\_\_\_  
 WQ stand./conventional poll.? yes/no If yes: value of standard \_\_\_\_\_  
 Any mixing zone specified? yes/no If yes: distance \_\_\_\_\_ m or width \_\_\_\_\_ % or m  
 or area \_\_\_\_\_ % or m<sup>2</sup>  
 Region of interest \_\_\_\_\_ m Grid intervals for display \_\_\_\_\_

25' - 30'  
7.62 - 9.144m




total diffuser area:


- 6 m<sup>2</sup>
- 6 m<sup>2</sup>
- 18 m<sup>2</sup>
- 18 m<sup>2</sup>
- 18 m<sup>2</sup>

$66 \text{ m}^2 \approx 0.4258 \text{ m}^2$

RS/16  
7-17-97



Rowile INC.



Weight above bottom

ave depth  $5 1/2 - (17 \cdot 1/2 + 8) = 26$

$56 - (29 + 8) = 19$

$54 - (41 + 8) = 5$

ave 16.3" (0.42672 m)

Ronile Inc  
 5-1-08  
 Roger McBride  
 measured 4/25/08



RONILE22.CX2

X-axis points downstream, Y-axis points to left, Z-axis points upward.  
 NSTEP = 50 display intervals per module

BEGIN MOD201: DIFFUSER DISCHARGE MODULE

Due to complex near-field motions: EQUIVALENT SLOT DIFFUSER (2-D) GEOMETRY

Profile definitions:

- BV = Gaussian 1/e (37%) half-width, in vertical plane normal to trajectory
- BH = top-hat half-width, in horizontal plane normal to trajectory
- S = hydrodynamic centerline dilution
- C = centerline concentration (includes reaction effects, if any)

X	Y	Z	S	C	BV	BH
.00	.00	.20	1.0	.100E+03	.02	.78

END OF MOD201: DIFFUSER DISCHARGE MODULE

BEGIN MOD271: ACCELERATION ZONE OF UNIDIRECTIONAL CO-FLOWING DIFFUSER

In this laterally contracting zone the diffuser plume becomes VERTICALLY FULLY MIXED over the entire layer depth (HS = .91m).

Full mixing is achieved after a plume distance of about five layer depths from the diffuser.

Profile definitions:

- BV = layer depth (vertically mixed)
- BH = top-hat half-width, in horizontal plane normal to trajectory
- S = hydrodynamic average (bulk) dilution
- C = average (bulk) concentration (includes reaction effects, if any)

X	Y	Z	S	C	BV	BH
.00	.00	.20	1.0	.100E+03	.02	.78
.02	.00	.21	2.0	.491E+02	.02	.77
.03	.00	.21	2.5	.406E+02	.04	.76
.05	.00	.22	2.8	.358E+02	.05	.76
.06	.00	.22	3.1	.325E+02	.07	.75
.08	.00	.23	3.3	.301E+02	.09	.74
.09	.00	.23	3.5	.283E+02	.11	.74
.11	.00	.24	3.7	.267E+02	.13	.73
.12	.00	.24	3.9	.254E+02	.15	.72
.14	.00	.25	4.1	.243E+02	.16	.72
.16	.00	.25	4.3	.234E+02	.18	.71
.17	.00	.26	4.4	.225E+02	.20	.71
.19	.00	.26	4.6	.218E+02	.22	.70
.20	.00	.27	4.7	.211E+02	.24	.70
.22	.00	.27	4.9	.205E+02	.25	.69
.23	.00	.28	5.0	.199E+02	.27	.69
.25	.00	.28	5.1	.194E+02	.29	.69
.27	.00	.29	5.3	.190E+02	.31	.68
.28	.00	.29	5.4	.185E+02	.33	.68
.30	.00	.30	5.5	.181E+02	.35	.68
.31	.00	.30	5.6	.177E+02	.36	.67
.33	.00	.31	5.8	.174E+02	.38	.67
.34	.00	.31	5.9	.171E+02	.40	.67
.36	.00	.32	6.0	.167E+02	.42	.66
.37	.00	.32	6.1	.165E+02	.44	.66
.39	.00	.33	6.2	.162E+02	.46	.66
.41	.00	.33	6.3	.159E+02	.47	.66
.42	.00	.34	6.4	.157E+02	.49	.65
.44	.00	.34	6.5	.154E+02	.51	.65
.45	.00	.35	6.6	.152E+02	.53	.65
.47	.00	.35	6.7	.150E+02	.55	.65
.48	.00	.36	6.8	.148E+02	.56	.64



RONILE22.CX2

.50	.00	.36	6.9	.146E+02	.58	.64
.52	.00	.37	7.0	.144E+02	.60	.64
→ .53	.00	.37	7.0	.142E+02	.62	.64
.55	.00	.38	7.1	.140E+02	.64	.64
.56	.00	.38	7.2	.139E+02	.66	.64
.58	.00	.39	7.3	.137E+02	.67	.64
.59	.00	.39	7.4	.135E+02	.69	.64
.61	.00	.40	7.5	.134E+02	.71	.63
.62	.00	.40	7.6	.132E+02	.73	.63
.64	.00	.41	7.6	.131E+02	.75	.63
.66	.00	.41	7.7	.130E+02	.76	.63
.67	.00	.42	7.8	.128E+02	.78	.63
.69	.00	.42	7.9	.127E+02	.80	.63
.70	.00	.43	8.0	.126E+02	.82	.63
.72	.00	.43	8.0	.125E+02	.84	.63
.73	.00	.44	8.1	.123E+02	.86	.63
.75	.00	.44	8.2	.122E+02	.87	.63
.77	.00	.45	8.3	.121E+02	.89	.63
.78	.00	.46	8.3	.120E+02	.91	.63

Cumulative travel time = 16. sec

END OF MOD271: ACCELERATION ZONE OF UNIDIRECTIONAL CO-FLOWING DIFFUSER

BEGIN MOD251: DIFFUSER PLUME IN CO-FLOW

Phase 1: Vertically mixed, Phase 2: Re-stratified

Phase 2: The flow has RESTRATIFIED at the beginning of this zone.

This flow region is INSIGNIFICANT in spatial extent and will be by-passed.

END OF MOD251: DIFFUSER PLUME IN CO-FLOW

\*\* End of NEAR-FIELD REGION (NFR) \*\*

The initial plume WIDTH values in the next far-field module will be CORRECTED by a factor 1.59 to conserve the mass flux in the far-field! The correction factor is quite large because of the small ambient velocity relative to the strong mixing characteristics of the discharge! This indicates localized RECIRCULATION REGIONS and internal hydraulic JUMPS.

BEGIN MOD241: BUOYANT AMBIENT SPREADING

Profile definitions:

- BV = top-hat thickness, measured vertically
- BH = top-hat half-width, measured horizontally in y-direction
- ZU = upper plume boundary (Z-coordinate)
- ZL = lower plume boundary (Z-coordinate)
- S = hydrodynamic average (bulk) dilution
- C = average (bulk) concentration (includes reaction effects, if any)

Plume Stage 1 (not bank attached):

X	Y	Z	S	C	BV	BH	ZU	ZL
.78	.00	.91	8.3	.120E+02	.91	1.00	.91	.00
1.10	.00	.91	8.5	.117E+02	.85	1.10	.91	.06
1.42	.00	.91	8.7	.115E+02	.80	1.19	.91	.11
1.73	.00	.91	8.9	.113E+02	.76	1.28	.91	.15
2.05	.00	.91	9.0	.111E+02	.73	1.36	.91	.18
2.37	.00	.91	9.2	.109E+02	.70	1.44	.91	.21
2.68	.00	.91	9.3	.107E+02	.67	1.52	.91	.24
3.00	.00	.91	9.5	.106E+02	.65	1.60	.91	.26
3.32	.00	.91	9.6	.104E+02	.63	1.68	.91	.28
3.64	.00	.91	9.7	.103E+02	.61	1.75	.91	.30
3.95	.00	.91	9.9	.101E+02	.59	1.83	.91	.32

RONILE22.CX2

4.27	.00	.91	10.0	.100E+02	.58	1.90	.91	.33
4.59	.00	.91	10.1	.989E+01	.56	1.97	.91	.35
4.91	.00	.91	10.2	.977E+01	.55	2.04	.91	.36
5.22	.00	.91	10.4	.966E+01	.54	2.10	.91	.37
5.54	.00	.91	10.5	.955E+01	.53	2.17	.91	.38
5.86	.00	.91	10.6	.944E+01	.52	2.24	.91	.39
6.17	.00	.91	10.7	.933E+01	.51	2.30	.91	.40
6.49	.00	.91	10.8	.923E+01	.50	2.36	.91	.41
6.81	.00	.91	11.0	.913E+01	.49	2.43	.91	.42
7.13	.00	.91	11.1	.903E+01	.49	2.49	.91	.42
7.44	.00	.91	11.2	.893E+01	.48	2.55	.91	.43
7.76	.00	.91	11.3	.883E+01	.48	2.61	.91	.43
8.08	.00	.91	11.4	.874E+01	.47	2.67	.91	.44
8.39	.00	.91	11.6	.864E+01	.46	2.73	.91	.45
8.71	.00	.91	11.7	.855E+01	.46	2.79	.91	.45
9.03	.00	.91	11.8	.846E+01	.46	2.85	.91	.45
9.35	.00	.91	12.0	.836E+01	.45	2.90	.91	.46
9.66	.00	.91	12.1	.827E+01	.45	2.96	.91	.46
9.98	.00	.91	12.2	.818E+01	.44	3.02	.91	.47
10.30	.00	.91	12.4	.809E+01	.44	3.07	.91	.47
10.62	.00	.91	12.5	.800E+01	.44	3.13	.91	.47
10.93	.00	.91	12.6	.792E+01	.43	3.18	.91	.48
11.25	.00	.91	12.8	.783E+01	.43	3.24	.91	.48
11.57	.00	.91	12.9	.774E+01	.43	3.29	.91	.48
11.88	.00	.91	13.1	.765E+01	.43	3.34	.91	.48
12.20	.00	.91	13.2	.757E+01	.43	3.40	.91	.48
12.52	.00	.91	13.4	.748E+01	.42	3.45	.91	.49
12.84	.00	.91	13.5	.740E+01	.42	3.50	.91	.49
13.15	.00	.91	13.7	.731E+01	.42	3.55	.91	.49
13.47	.00	.91	13.8	.723E+01	.42	3.60	.91	.49
13.79	.00	.91	14.0	.715E+01	.42	3.66	.91	.49
14.10	.00	.91	14.2	.706E+01	.42	3.71	.91	.49
14.42	.00	.91	14.3	.698E+01	.42	3.76	.91	.49
14.74	.00	.91	14.5	.690E+01	.42	3.81	.91	.49
15.06	.00	.91	14.7	.682E+01	.42	3.86	.91	.49
15.37	.00	.91	14.8	.674E+01	.42	3.91	.91	.49
15.69	.00	.91	15.0	.666E+01	.42	3.95	.91	.49
16.01	.00	.91	15.2	.658E+01	.42	4.00	.91	.49
16.33	.00	.91	15.4	.650E+01	.42	4.05	.91	.49
16.64	.00	.91	15.6	.642E+01	.42	4.10	.91	.49
Cumulative travel time =			549. sec					

-----  
 Plume is ATTACHED to LEFT bank/shore.  
 Plume width is now determined from LEFT bank/shore.

Plume stage 2 (bank attached):

X	Y	Z	S	C	BV	BH	ZU	ZL
16.64	4.10	.91	15.6	.642E+01	.42	8.20	.91	.49
16.99	4.10	.91	15.8	.635E+01	.42	8.25	.91	.49
17.35	4.10	.91	15.9	.627E+01	.42	8.30	.91	.49
17.70	4.10	.91	16.1	.620E+01	.42	8.35	.91	.49
18.05	4.10	.91	16.3	.613E+01	.43	8.41	.91	.48
18.40	4.10	.91	16.5	.605E+01	.43	8.46	.91	.48
18.75	4.10	.91	16.7	.598E+01	.43	8.51	.91	.48
19.11	4.10	.91	16.9	.591E+01	.43	8.56	.91	.48
19.46	4.10	.91	17.1	.584E+01	.44	8.62	.91	.47
19.81	4.10	.91	17.3	.577E+01	.44	8.67	.91	.47
20.16	4.10	.91	17.5	.571E+01	.44	8.72	.91	.47
20.51	4.10	.91	17.7	.564E+01	.44	8.77	.91	.47
20.87	4.10	.91	17.9	.557E+01	.45	8.82	.91	.46
21.22	4.10	.91	18.1	.551E+01	.45	8.87	.91	.46
21.57	4.10	.91	18.4	.545E+01	.45	8.92	.91	.46
21.92	4.10	.91	18.6	.538E+01	.45	8.97	.91	.46
22.28	4.10	.91	18.8	.532E+01	.46	9.02	.91	.45
22.63	4.10	.91	19.0	.526E+01	.46	9.08	.91	.45

RONILE22.CX2

22.98	4.10	.91	19.2	.520E+01	.46	9.13	.91	.45
23.33	4.10	.91	19.5	.514E+01	.46	9.18	.91	.45
23.68	4.10	.91	19.7	.508E+01	.47	9.23	.91	.44
24.04	4.10	.91	19.9	.502E+01	.47	9.28	.91	.44
24.39	4.10	.91	20.2	.496E+01	.47	9.33	.91	.44
24.74	4.10	.91	20.4	.491E+01	.48	9.38	.91	.43
25.09	4.10	.91	20.6	.485E+01	.48	9.42	.91	.43
25.44	4.10	.91	20.9	.479E+01	.48	9.47	.91	.43
25.80	4.10	.91	21.1	.474E+01	.49	9.52	.91	.42
26.15	4.10	.91	21.3	.468E+01	.49	9.57	.91	.42
26.50	4.10	.91	21.6	.463E+01	.49	9.62	.91	.42
26.85	4.10	.91	21.8	.458E+01	.49	9.67	.91	.42
27.20	4.10	.91	22.1	.453E+01	.50	9.72	.91	.41
27.56	4.10	.91	22.3	.448E+01	.50	9.77	.91	.41
27.91	4.10	.91	22.6	.443E+01	.50	9.82	.91	.41
28.26	4.10	.91	22.9	.438E+01	.51	9.87	.91	.40
28.61	4.10	.91	23.1	.433E+01	.51	9.91	.91	.40
28.96	4.10	.91	23.4	.428E+01	.51	9.96	.91	.40
29.32	4.10	.91	23.6	.423E+01	.52	10.01	.91	.39
29.67	4.10	.91	23.9	.418E+01	.52	10.06	.91	.39
30.02	4.10	.91	24.2	.414E+01	.52	10.11	.91	.39
30.37	4.10	.91	24.4	.409E+01	.53	10.15	.91	.38
30.72	4.10	.91	24.7	.405E+01	.53	10.20	.91	.38
31.08	4.10	.91	25.0	.400E+01	.53	10.25	.91	.38
31.43	4.10	.91	25.3	.396E+01	.54	10.30	.91	.37
31.78	4.10	.91	25.6	.391E+01	.54	10.34	.91	.37
32.13	4.10	.91	25.8	.387E+01	.54	10.39	.91	.37
32.48	4.10	.91	26.1	.383E+01	.55	10.44	.91	.36
32.84	4.10	.91	26.4	.379E+01	.55	10.48	.91	.36
33.19	4.10	.91	26.7	.374E+01	.56	10.53	.91	.35
33.54	4.10	.91	27.0	.370E+01	.56	10.58	.91	.35
33.89	4.10	.91	27.3	.366E+01	.56	10.62	.91	.35
34.24	4.10	.91	27.6	.362E+01	.57	10.67	.91	.34

Cumulative travel time = 1140. sec

Plume is LATERALLY FULLY MIXED at the end of the buoyant spreading regime.

END OF MOD241: BUOYANT AMBIENT SPREADING

-----  
 Bottom coordinate for FAR-FIELD is determined by average depth, ZFB = .09m  
 -----

BEGIN MOD261: PASSIVE AMBIENT MIXING IN UNIFORM AMBIENT

Vertical diffusivity (initial value) = .728E-03 m<sup>2</sup>/s

Horizontal diffusivity (initial value) = .909E-03 m<sup>2</sup>/s

Profile definitions:

BV = Gaussian s.d.\*sqrt(pi/2) (46%) thickness, measured vertically  
 = or equal to layer depth, if fully mixed

BH = Gaussian s.d.\*sqrt(pi/2) (46%) half-width,  
 measured horizontally in Y-direction

ZU = upper plume boundary (Z-coordinate)

ZL = lower plume boundary (Z-coordinate)

S = hydrodynamic centerline dilution

C = centerline concentration (includes reaction effects, if any)

Plume stage 2 (bank attached):

X	Y	Z	S	C	BV	BH	ZU	ZL
34.24	4.10	.91	27.6	.362E+01	.57	10.67	.91	.34

Plume interacts with BOTTOM.

The passive diffusion plume becomes VERTICALLY FULLY MIXED within this prediction interval.

73.56	4.10	.91	39.9	.250E+01	.82	10.67	.91	.09
-------	------	-----	------	----------	-----	-------	-----	-----

Effluent is FULLY MIXED over the entire channel cross-section.

Except for possible far-field decay or reaction processes, there are NO FURTHER CHANGES with downstream direction.

112.87	4.10	.91	39.9	.250E+01	.82	10.67	.91	.09
--------	------	-----	------	----------	-----	-------	-----	-----





X-axis points downstream, Y-axis points to left, Z-axis points upward.  
 NSTEP = 50 display intervals per module

BEGIN MOD201: DIFFUSER DISCHARGE MODULE

Due to complex near-field motions: EQUIVALENT SLOT DIFFUSER (2-D) GEOMETRY

Profile definitions:

- BV = Gaussian 1/e (37%) half-width, in vertical plane normal to trajectory
- BH = top-hat half-width, in horizontal plane normal to trajectory
- S = hydrodynamic centerline dilution
- C = centerline concentration (includes reaction effects, if any)

X	Y	Z	S	C	BV	BH
.00	.00	.25	1.0	.100E+03	.02	.78

END OF MOD201: DIFFUSER DISCHARGE MODULE

BEGIN MOD271: ACCELERATION ZONE OF UNIDIRECTIONAL CO-FLOWING DIFFUSER

In this laterally contracting zone the diffuser plume becomes VERTICALLY FULLY MIXED over the entire layer depth (HS = .91m).  
 Full mixing is achieved after a plume distance of about five layer depths from the diffuser.

Profile definitions:

- BV = layer depth (vertically mixed)
- BH = top-hat half-width, in horizontal plane normal to trajectory
- S = hydrodynamic average (bulk) dilution
- C = average (bulk) concentration (includes reaction effects, if any)

X	Y	Z	S	C	BV	BH
.00	.00	.25	1.0	.100E+03	.02	.78
.02	.00	.25	2.1	.471E+02	.02	.77
.03	.00	.26	2.6	.386E+02	.04	.77
.05	.00	.26	2.9	.339E+02	.05	.76
.06	.00	.27	3.2	.308E+02	.07	.75
.08	.00	.27	3.5	.284E+02	.09	.75
.09	.00	.27	3.8	.266E+02	.11	.74
.11	.00	.28	4.0	.252E+02	.13	.73
.12	.00	.28	4.2	.239E+02	.15	.73
.14	.00	.29	4.4	.229E+02	.16	.72
.16	.00	.29	4.6	.219E+02	.18	.72
.17	.00	.30	4.7	.211E+02	.20	.72
.19	.00	.30	4.9	.204E+02	.22	.71
.20	.00	.30	5.1	.198E+02	.24	.71
.22	.00	.31	5.2	.192E+02	.25	.70
.23	.00	.31	5.4	.187E+02	.27	.70
.25	.00	.32	5.5	.182E+02	.29	.70
.27	.00	.32	5.6	.177E+02	.31	.69
.28	.00	.32	5.8	.173E+02	.33	.69
.30	.00	.33	5.9	.169E+02	.35	.69
.31	.00	.33	6.0	.166E+02	.36	.68
.33	.00	.34	6.2	.162E+02	.38	.68
.34	.00	.34	6.3	.159E+02	.40	.68
.36	.00	.34	6.4	.156E+02	.42	.68
.37	.00	.35	6.5	.154E+02	.44	.67
.39	.00	.35	6.6	.151E+02	.46	.67
.41	.00	.36	6.7	.148E+02	.47	.67
.42	.00	.36	6.8	.146E+02	.49	.67
.44	.00	.36	7.0	.144E+02	.51	.67
.45	.00	.37	7.1	.142E+02	.53	.66
.47	.00	.37	7.2	.140E+02	.55	.66
.48	.00	.38	7.3	.138E+02	.56	.66

RONILE24.CX2

.50	.00	.38	7.4	.136E+02	.58	.66
.52	.00	.39	7.5	.134E+02	.60	.66
.53	.00	.39	7.6	.132E+02	.62	.66
.55	.00	.39	7.7	.131E+02	.64	.65
.56	.00	.40	7.7	.129E+02	.66	.65
.58	.00	.40	7.8	.128E+02	.67	.65
.59	.00	.41	7.9	.126E+02	.69	.65
.61	.00	.41	8.0	.125E+02	.71	.65
.62	.00	.41	8.1	.123E+02	.73	.65
.64	.00	.42	8.2	.122E+02	.75	.65
.66	.00	.42	8.3	.121E+02	.76	.65
.67	.00	.43	8.4	.119E+02	.78	.65
.69	.00	.43	8.5	.118E+02	.80	.65
.70	.00	.43	8.5	.117E+02	.82	.65
.72	.00	.44	8.6	.116E+02	.84	.65
.73	.00	.44	8.7	.115E+02	.86	.65
.75	.00	.45	8.8	.114E+02	.87	.65
.77	.00	.45	8.9	.113E+02	.89	.65
.78	.00	.46	9.0	.112E+02	.91	.65

Cumulative travel time = 16. sec

END OF MOD271: ACCELERATION ZONE OF UNIDIRECTIONAL CO-FLOWING DIFFUSER

BEGIN MOD251: DIFFUSER PLUME IN CO-FLOW

Phase 1: Vertically mixed, Phase 2: Re-stratified

Phase 2: The flow has RESTRATIFIED at the beginning of this zone.

This flow region is INSIGNIFICANT in spatial extent and will be by-passed.

END OF MOD251: DIFFUSER PLUME IN CO-FLOW

\*\* End of NEAR-FIELD REGION (NFR) \*\*

The initial plume WIDTH values in the next far-field module will be CORRECTED by a factor 1.49 to conserve the mass flux in the far-field!

BEGIN MOD241: BUOYANT AMBIENT SPREADING

Profile definitions:

- BV = top-hat thickness, measured vertically
- BH = top-hat half-width, measured horizontally in y-direction
- ZU = upper plume boundary (Z-coordinate)
- ZL = lower plume boundary (Z-coordinate)
- S = hydrodynamic average (bulk) dilution
- C = average (bulk) concentration (includes reaction effects, if any)

Plume stage 1 (not bank attached):

X	Y	Z	S	C	BV	BH	ZU	ZL
.78	.00	.91	9.0	.112E+02	.91	.96	.91	.00
1.16	.00	.91	9.2	.109E+02	.85	1.06	.91	.06
1.54	.00	.91	9.4	.106E+02	.80	1.16	.91	.11
1.91	.00	.91	9.6	.104E+02	.76	1.24	.91	.15
2.29	.00	.91	9.8	.102E+02	.72	1.33	.91	.19
2.67	.00	.91	10.0	.100E+02	.69	1.42	.91	.22
3.05	.00	.91	10.1	.986E+01	.66	1.50	.91	.25
3.43	.00	.91	10.3	.970E+01	.64	1.58	.91	.27
3.80	.00	.91	10.5	.955E+01	.62	1.65	.91	.29
4.18	.00	.91	10.6	.940E+01	.60	1.73	.91	.31
4.56	.00	.91	10.8	.926E+01	.59	1.80	.91	.32
4.94	.00	.91	11.0	.913E+01	.57	1.87	.91	.34
5.31	.00	.91	11.1	.900E+01	.56	1.95	.91	.35
5.69	.00	.91	11.3	.887E+01	.55	2.02	.91	.36

RONILE24.CX2

6.07	.00	.91	11.4	.875E+01	.54	2.08	.91	.37
6.45	.00	.91	11.6	.863E+01	.53	2.15	.91	.38
6.82	.00	.91	11.7	.851E+01	.52	2.22	.91	.39
7.20	.00	.91	11.9	.839E+01	.51	2.28	.91	.40
7.58	.00	.91	12.1	.828E+01	.50	2.35	.91	.41
7.96	.00	.91	12.2	.817E+01	.50	2.41	.91	.41
8.34	.00	.91	12.4	.806E+01	.49	2.47	.91	.42
8.71	.00	.91	12.6	.794E+01	.49	2.54	.91	.42
9.09	.00	.91	12.8	.784E+01	.48	2.60	.91	.43
9.47	.00	.91	12.9	.773E+01	.48	2.66	.91	.43
9.85	.00	.91	13.1	.762E+01	.47	2.72	.91	.44
10.22	.00	.91	13.3	.751E+01	.47	2.78	.91	.44
10.60	.00	.91	13.5	.741E+01	.47	2.83	.91	.44
10.98	.00	.91	13.7	.730E+01	.46	2.89	.91	.45
11.36	.00	.91	13.9	.720E+01	.46	2.95	.91	.45
11.74	.00	.91	14.1	.710E+01	.46	3.01	.91	.45
12.11	.00	.91	14.3	.699E+01	.46	3.06	.91	.45
12.49	.00	.91	14.5	.689E+01	.46	3.12	.91	.45
12.87	.00	.91	14.7	.679E+01	.45	3.17	.91	.46
13.25	.00	.91	14.9	.669E+01	.45	3.23	.91	.46
13.62	.00	.91	15.2	.659E+01	.45	3.28	.91	.46
14.00	.00	.91	15.4	.650E+01	.45	3.34	.91	.46
14.38	.00	.91	15.6	.640E+01	.45	3.39	.91	.46
14.76	.00	.91	15.9	.630E+01	.45	3.44	.91	.46
15.14	.00	.91	16.1	.621E+01	.45	3.50	.91	.46
15.51	.00	.91	16.4	.611E+01	.45	3.55	.91	.46
15.89	.00	.91	16.6	.602E+01	.45	3.60	.91	.46
16.27	.00	.91	16.9	.593E+01	.45	3.65	.91	.46
16.65	.00	.91	17.1	.583E+01	.45	3.70	.91	.46
17.02	.00	.91	17.4	.574E+01	.45	3.75	.91	.46
17.40	.00	.91	17.7	.565E+01	.46	3.80	.91	.45
17.78	.00	.91	18.0	.557E+01	.46	3.85	.91	.45
18.16	.00	.91	18.3	.548E+01	.46	3.90	.91	.45
18.53	.00	.91	18.5	.539E+01	.46	3.95	.91	.45
18.91	.00	.91	18.8	.531E+01	.46	4.00	.91	.45
19.29	.00	.91	19.1	.522E+01	.46	4.05	.91	.45
19.67	.00	.91	19.5	.514E+01	.47	4.10	.91	.44

Cumulative travel time = 583. sec

halfwidth(BH) =  
5.33 in this region  
S = 19.5

Plume is ATTACHED to LEFT bank/shore.  
Plume width is now determined from LEFT bank/shore.

Plume Stage 2 (bank attached):

X	Y	Z	S	C	BV	BH	ZU	ZL
19.67	4.10	.91	→ 19.5	.514E+01	.47	8.20	.91	.44
20.08	4.10	.91	19.8	.506E+01	.47	8.25	.91	.44
20.50	4.10	.91	20.1	.498E+01	.47	8.30	.91	.44
20.91	4.10	.91	20.4	.490E+01	.48	8.35	.91	.43
21.33	4.10	.91	20.7	.482E+01	.48	8.41	.91	.43
21.75	4.10	.91	21.1	.475E+01	.49	8.46	.91	.42
22.16	4.10	.91	21.4	.467E+01	.49	8.51	.91	.42
22.58	4.10	.91	21.7	.460E+01	.50	8.56	.91	.41
22.99	4.10	.91	22.1	.453E+01	.50	8.62	.91	.41
23.41	4.10	.91	22.4	.446E+01	.51	8.67	.91	.40
23.82	4.10	.91	22.8	.439E+01	.51	8.72	.91	.40
24.24	4.10	.91	23.1	.432E+01	.52	8.77	.91	.39
24.65	4.10	.91	23.5	.426E+01	.52	8.82	.91	.39
25.07	4.10	.91	23.8	.419E+01	.53	8.87	.91	.38
25.48	4.10	.91	24.2	.413E+01	.53	8.92	.91	.38
25.90	4.10	.91	24.6	.407E+01	.54	8.97	.91	.37
26.32	4.10	.91	25.0	.401E+01	.54	9.02	.91	.37
26.73	4.10	.91	25.3	.395E+01	.55	9.07	.91	.36
27.15	4.10	.91	25.7	.389E+01	.55	9.13	.91	.36
27.56	4.10	.91	26.1	.383E+01	.56	9.18	.91	.35
27.98	4.10	.91	26.5	.377E+01	.56	9.23	.91	.35



RONILE24.CX2

28.39	4.10	.91	26.9	.372E+01	.57	9.28	.91	.34
28.81	4.10	.91	27.3	.367E+01	.57	9.33	.91	.34
29.22	4.10	.91	27.7	.361E+01	.58	9.37	.91	.33
29.64	4.10	.91	28.1	.356E+01	.58	9.42	.91	.33
30.05	4.10	.91	28.5	.351E+01	.59	9.47	.91	.32
30.47	4.10	.91	28.9	.346E+01	.60	9.52	.91	.31
30.89	4.10	.91	29.3	.341E+01	.60	9.57	.91	.31
31.30	4.10	.91	29.8	.336E+01	.61	9.62	.91	.30
31.72	4.10	.91	30.2	.331E+01	.61	9.67	.91	.30
32.13	4.10	.91	30.6	.327E+01	.62	9.72	.91	.29
32.55	4.10	.91	31.1	.322E+01	.62	9.77	.91	.29
32.96	4.10	.91	31.5	.318E+01	.63	9.82	.91	.28
33.38	4.10	.91	31.9	.313E+01	.63	9.86	.91	.28
33.79	4.10	.91	32.4	.309E+01	.64	9.91	.91	.27
34.21	4.10	.91	32.8	.305E+01	.65	9.96	.91	.26
34.62	4.10	.91	33.3	.300E+01	.65	10.01	.91	.26
35.04	4.10	.91	33.8	.296E+01	.66	10.06	.91	.25
35.46	4.10	.91	34.2	.292E+01	.66	10.11	.91	.25
35.87	4.10	.91	34.7	.288E+01	.67	10.15	.91	.24
36.29	4.10	.91	35.2	.284E+01	.68	10.20	.91	.23
36.70	4.10	.91	35.6	.281E+01	.68	10.25	.91	.23
37.12	4.10	.91	36.1	.277E+01	.69	10.30	.91	.22
37.53	4.10	.91	36.6	.273E+01	.69	10.34	.91	.22
37.95	4.10	.91	37.1	.269E+01	.70	10.39	.91	.21
38.36	4.10	.91	37.6	.266E+01	.71	10.44	.91	.20
38.78	4.10	.91	38.1	.262E+01	.71	10.48	.91	.20
39.19	4.10	.91	38.6	.259E+01	.72	10.53	.91	.19
39.61	4.10	.91	39.1	.256E+01	.72	10.58	.91	.19
40.03	4.10	.91	39.6	.252E+01	.73	10.62	.91	.18
40.44	4.10	.91	40.1	.249E+01	.74	10.67	.91	.17

Cumulative travel time = 1207. sec

Plume is LATERALLY FULLY MIXED at the end of the buoyant spreading regime.

END OF MOD241: BUOYANT AMBIENT SPREADING

Bottom coordinate for FAR-FIELD is determined by average depth, ZFB = .09m

BEGIN MOD261: PASSIVE AMBIENT MIXING IN UNIFORM AMBIENT

Vertical diffusivity (initial value) = .802E-03 m<sup>2</sup>/s  
 Horizontal diffusivity (initial value) = .100E-02 m<sup>2</sup>/s

Profile definitions:

- BV = Gaussian s.d.\*sqrt(pi/2) (46%) thickness, measured vertically  
 = or equal to layer depth, if fully mixed
- BH = Gaussian s.d.\*sqrt(pi/2) (46%) half-width,  
 measured horizontally in Y-direction
- ZU = upper plume boundary (Z-coordinate)
- ZL = lower plume boundary (Z-coordinate)
- S = hydrodynamic centerline dilution
- C = centerline concentration (includes reaction effects, if any)

Plume stage 2 (bank attached):

X	Y	Z	S	C	BV	BH	ZU	ZL
40.44	4.10	.91	40.1	.249E+01	.74	10.67	.91	.17

Plume interacts with BOTTOM.

The passive diffusion plume becomes VERTICALLY FULLY MIXED within this prediction interval.

79.63	4.10	.91	44.6	.224E+01	.82	10.67	.91	.09
-------	------	-----	------	----------	-----	-------	-----	-----

Effluent is FULLY MIXED over the entire channel cross-section.

Except for possible far-field decay or reaction processes, there are NO FURTHER CHANGES with downstream direction.

118.82	4.10	.91	44.6	.224E+01	.82	10.67	.91	.09
158.01	4.10	.91	44.6	.224E+01	.82	10.67	.91	.09
197.21	4.10	.91	44.6	.224E+01	.82	10.67	.91	.09
236.40	4.10	.91	44.6	.224E+01	.82	10.67	.91	.09



# FRESHWATER WATER QUALITY CRITERIA / WASTELOAD ALLOCATION ANALYSIS

Facility Name: **Ronile Inc 001 CORMIX DILUTIONS**

Permit No.: **VA0076015**

Receiving Stream: **Pigg River**

Version: OWP Guidance Memo 00-2011 (8/24/00)

Stream Information	Stream Flows	Mixing Information	Effluent Information				
Mean Hardness (as CaCO3) =	30 mg/L	1Q10 (Annual) =	6 MGD	Annual - 1Q10 Mix =	100 %	Mean Hardness (as CaCO3) =	152 mg/L
90% Temperature (Annual) =	22.7 deg C	7Q10 (Annual) =	18.5 MGD	- 7Q10 Mix =	100 %	90% Temp (Annual) =	29 deg C
90% Temperature (Wet season) =	22.7 deg C	3Q10 (Annual) =	25 MGD	- 3Q10 Mix =	100 %	90% Temp (Wet season) =	17 deg C
90% Maximum pH =	7.4 SU	1Q10 (Wet season) =	6 MGD	Wet Season - 1Q10 Mix =	100 %	90% Maximum pH =	7.95 SU
10% Maximum pH =	6.1 SU	3Q10 (Wet season) =	25 MGD	- 3Q10 Mix =	100 %	10% Maximum pH =	6.72 SU
Tier Designation (1 or 2) =	2	3Q5 =	25 MGD			Discharge Flow =	1 MGD
Public Water Supply (PWS) Y/N? =	N	Harmonic Mean =	25 MGD				
Trout Present Y/N? =	n						
Early Life Stages Present Y/N? =	y						

Parameter (ug/l unless noted)	Background Conc.	Water Quality Criteria				Wasteload Allocations				Antidegradation Baseline				Antidegradation Allocations				Most Limiting Allocations				Method Target Value
		Acute	Chronic	HH (PWS)	HH	Acute	Chronic	HH (PWS)	HH	Acute	Chronic	HH (PWS)	HH	Acute	Chronic	HH (PWS)	HH	Acute	Chronic	HH (PWS)	HH	
Acenaphthene	0	--	--	na	9.9E+02	--	--	na	2.6E+04	--	--	na	9.9E+01	--	--	na	2.6E+03	--	--	na	2.6E+03	2.6E+03
Acrolein	0	3.0E+00	3.0E+00	na	9.3E+00	2.1E+01	5.9E+01	na	2.4E+02	7.5E-01	7.5E-01	na	9.3E-01	5.3E+00	1.5E+01	na	2.4E+01	5.3E+00	1.5E+01	na	2.4E+01	2.1E+00
Acrylonitrile <sup>c</sup>	0	--	--	na	2.5E+00	--	--	na	6.5E+01	--	--	na	2.5E-01	--	--	na	6.5E+00	--	--	na	6.5E+00	6.5E+00
Aldrin <sup>c</sup>	0	3.0E+00	--	na	5.0E-04	2.1E+01	--	na	1.3E-02	7.5E-01	--	na	5.0E-05	5.3E+00	--	na	1.3E-03	5.3E+00	--	na	1.3E-03	1.3E-03
Ammonia-N (mg/l) (Yearly)	0	2.15E+01	2.72E+00	na	--	1.50E+02	7.08E+01	na	--	5.37E+00	6.81E-01	na	--	3.76E+01	1.77E+01	na	--	3.76E+01	1.77E+01	na	--	1.1E+01
Ammonia-N (mg/l) (High Flow)	0	2.15E+01	2.81E+00	na	--	1.50E+02	7.30E+01	na	--	5.37E+00	7.02E-01	na	--	3.76E+01	1.82E+01	na	--	3.76E+01	1.82E+01	na	--	1.1E+01
Anthracene	0	--	--	na	4.0E+04	--	--	na	1.0E+06	--	--	na	4.0E+03	--	--	na	1.0E+05	--	--	na	1.0E+05	1.0E+05
Antimony	0	--	--	na	6.4E+02	--	--	na	1.7E+04	--	--	na	6.4E+01	--	--	na	1.7E+03	--	--	na	1.7E+03	1.7E+03
Arsenic	0.28	3.4E+02	1.5E+02	na	--	2.4E+03	2.9E+03	na	--	8.5E+01	3.8E+01	na	--	5.9E+02	7.3E+02	na	--	5.9E+02	7.3E+02	na	--	2.4E+02
Barium	19	--	--	na	--	--	--	na	--	--	--	na	--	--	--	na	--	--	--	na	--	0.0E+00
Benzene <sup>c</sup>	0	--	--	na	5.1E+02	--	--	na	1.3E+04	--	--	na	5.1E+01	--	--	na	1.3E+03	--	--	na	1.3E+03	1.3E+03
Benzidine <sup>c</sup>	0	--	--	na	2.0E-03	--	--	na	5.2E-02	--	--	na	2.0E-04	--	--	na	5.2E-03	--	--	na	5.2E-03	5.2E-03
Benzo (a) anthracene <sup>c</sup>	0	--	--	na	1.8E-01	--	--	na	4.7E+00	--	--	na	1.8E-02	--	--	na	4.7E-01	--	--	na	4.7E-01	4.7E-01
Benzo (b) fluoranthene <sup>c</sup>	0	--	--	na	1.8E-01	--	--	na	4.7E+00	--	--	na	1.8E-02	--	--	na	4.7E-01	--	--	na	4.7E-01	4.7E-01
Benzo (k) fluoranthene <sup>c</sup>	0	--	--	na	1.8E-01	--	--	na	4.7E+00	--	--	na	1.8E-02	--	--	na	4.7E-01	--	--	na	4.7E-01	4.7E-01
Benzo (a) pyrene <sup>c</sup>	0	--	--	na	1.8E-01	--	--	na	4.7E+00	--	--	na	1.8E-02	--	--	na	4.7E-01	--	--	na	4.7E-01	4.7E-01
Bis2-Chloroethyl Ether <sup>c</sup>	0	--	--	na	5.3E+00	--	--	na	1.4E+02	--	--	na	5.3E-01	--	--	na	1.4E+01	--	--	na	1.4E+01	1.4E+01
Bis2-Chloroisopropyl Ether	0	--	--	na	6.5E+04	--	--	na	1.7E+06	--	--	na	6.5E+03	--	--	na	1.7E+05	--	--	na	1.7E+05	1.7E+05
Bis 2-Ethylhexyl Phthalate <sup>c</sup>	0	--	--	na	2.2E+01	--	--	na	5.7E+02	--	--	na	2.2E+00	--	--	na	5.7E+01	--	--	na	5.7E+01	5.7E+01
Bromoform <sup>c</sup>	0	--	--	na	1.4E+03	--	--	na	3.6E+04	--	--	na	1.4E+02	--	--	na	3.6E+03	--	--	na	3.6E+03	3.6E+03
Butylbenzylphthalate	0	--	--	na	1.9E+03	--	--	na	4.9E+04	--	--	na	1.9E+02	--	--	na	4.9E+03	--	--	na	4.9E+03	4.9E+03
Cadmium	0	1.7E+00	5.1E-01	na	--	1.2E+01	1.0E+01	na	--	4.2E-01	1.3E-01	na	--	3.0E+00	2.5E+00	na	--	3.0E+00	2.5E+00	na	--	1.2E+00
Carbon Tetrachloride <sup>c</sup>	0	--	--	na	1.6E+01	--	--	na	4.2E+02	--	--	na	1.6E+00	--	--	na	4.2E+01	--	--	na	4.2E+01	4.2E+01
Carbaryl	0	2.1E+00	2.1E+00	na	--	1.5E+01	4.1E+01	na	--	5.3E-01	5.3E-01	na	--	3.7E+00	1.0E+01	na	--	3.7E+00	1.0E+01	na	--	1.5E+00
Chlordane <sup>c</sup>	0	2.4E+00	4.3E-03	na	8.1E-03	1.7E+01	8.4E-02	na	2.1E-01	6.0E-01	1.1E-03	na	8.1E-04	4.2E+00	2.1E-02	na	2.1E-02	4.2E+00	2.1E-02	na	2.1E-02	1.3E-02
Chloride	0	8.6E+05	2.3E+05	na	--	6.0E+06	4.5E+06	na	--	2.2E+05	5.8E+04	na	--	1.5E+06	1.1E+06	na	--	1.5E+06	1.1E+06	na	--	6.0E+05
TRC	0	1.9E+01	1.1E+01	na	--	1.3E+02	2.1E+02	na	--	4.8E+00	2.8E+00	na	--	3.3E+01	5.4E+01	na	--	3.3E+01	5.4E+01	na	--	1.3E+01
Chlorobenzene	0	--	--	na	1.6E+03	--	--	na	4.2E+04	--	--	na	1.6E+02	--	--	na	4.2E+03	--	--	na	4.2E+03	4.2E+03

Parameter (ug/l unless noted)	Background Conc.	Water Quality Criteria				Wasteload Allocations				Antidegradation Baseline				Antidegradation Allocations				Most Limiting Allocations				Method Target Value
		Acute	Chronic	HH (PWS)	HH	Acute	Chronic	HH (PWS)	HH	Acute	Chronic	HH (PWS)	HH	Acute	Chronic	HH (PWS)	HH	Acute	Chronic	HH (PWS)	HH	
Chlorodibromomethane <sup>C</sup>	0	--	--	na	1.3E+02	--	--	na	3.4E+03	--	--	na	1.3E+01	--	--	na	3.4E+02	--	--	na	3.4E+02	3.4E+02
Chloroform	0	--	--	na	1.1E+04	--	--	na	2.9E+05	--	--	na	1.1E+03	--	--	na	2.9E+04	--	--	na	2.9E+04	2.9E+04
2-Chloronaphthalene	0	--	--	na	1.6E+03	--	--	na	4.2E+04	--	--	na	1.6E+02	--	--	na	4.2E+03	--	--	na	4.2E+03	4.2E+03
2-Chlorophenol	0	--	--	na	1.5E+02	--	--	na	3.9E+03	--	--	na	1.5E+01	--	--	na	3.9E+02	--	--	na	3.9E+02	3.9E+02
Chlorpyrifos	0	8.3E-02	4.1E-02	na	--	5.8E-01	8.0E-01	na	--	2.1E-02	1.0E-02	na	--	1.5E-01	2.0E-01	na	--	1.5E-01	2.0E-01	na	--	5.8E-02
Chromium III	0.12	3.1E+02	3.2E+01	na	--	2.2E+03	6.3E+02	na	--	7.7E+01	8.2E+00	na	--	5.4E+02	1.6E+02	na	--	5.4E+02	1.6E+02	na	--	9.4E+01
Chromium VI	0	1.6E+01	1.1E+01	na	--	1.1E+02	2.1E+02	na	--	4.0E+00	2.8E+00	na	--	2.8E+01	5.4E+01	na	--	2.8E+01	5.4E+01	na	--	1.1E+01
Chromium, Total	0.12	--	--	1.0E+02	--	--	--	na	--	--	--	1.0E+01	--	--	--	2.6E+02	--	--	--	na	--	0.0E+00
Chrysene <sup>C</sup>	0	--	--	3.8E-02	1.8E-02	--	--	na	4.7E-01	--	--	3.8E-03	1.8E-03	--	--	9.9E-02	4.7E-02	--	--	na	4.7E-02	4.7E-02
Copper	0.68	6.7E+00	3.8E+00	na	--	4.3E+01	6.1E+01	na	--	2.2E+00	1.5E+00	na	--	1.1E+01	1.6E+01	na	--	1.1E+01	1.6E+01	na	--	4.5E+00
Cyanide, Free	0	2.2E+01	5.2E+00	na	1.6E+04	1.5E+02	1.0E+02	na	4.2E+05	5.5E+00	1.3E+00	na	1.6E+03	3.9E+01	2.5E+01	na	4.2E+04	3.9E+01	2.5E+01	na	4.2E+04	1.5E+01
DDD <sup>C</sup>	0	--	--	na	3.1E-03	--	--	na	8.1E-02	--	--	na	3.1E-04	--	--	na	8.1E-03	--	--	na	8.1E-03	8.1E-03
DDE <sup>C</sup>	0	--	--	na	2.2E-03	--	--	na	5.7E-02	--	--	na	2.2E-04	--	--	na	5.7E-03	--	--	na	5.7E-03	5.7E-03
DDT <sup>C</sup>	0	1.1E+00	1.0E-03	na	2.2E-03	7.7E+00	2.0E-02	na	5.7E-02	2.8E-01	2.5E-04	na	2.2E-04	1.9E+00	4.9E-03	na	5.7E-03	1.9E+00	4.9E-03	na	5.7E-03	2.9E-03
Demeton	0	--	1.0E-01	na	--	--	2.0E+00	na	--	--	2.5E-02	na	--	--	4.9E-01	na	--	--	4.9E-01	na	--	4.9E-01
Diazinon	0	1.7E-01	1.7E-01	na	--	1.2E+00	3.3E+00	na	--	4.3E-02	4.3E-02	na	--	3.0E-01	8.3E-01	na	--	3.0E-01	8.3E-01	na	--	1.2E-01
Dibenz(a,h)anthracene <sup>C</sup>	0	--	--	na	1.8E-01	--	--	na	4.7E+00	--	--	na	1.8E-02	--	--	na	4.7E-01	--	--	na	4.7E-01	4.7E-01
1,2-Dichlorobenzene	0	--	--	na	1.3E+03	--	--	na	3.4E+04	--	--	na	1.3E+02	--	--	na	3.4E+03	--	--	na	3.4E+03	3.4E+03
1,3-Dichlorobenzene	0	--	--	na	9.6E+02	--	--	na	2.5E+04	--	--	na	9.6E+01	--	--	na	2.5E+03	--	--	na	2.5E+03	2.5E+03
1,4-Dichlorobenzene	0	--	--	na	1.9E+02	--	--	na	4.9E+03	--	--	na	1.9E+01	--	--	na	4.9E+02	--	--	na	4.9E+02	4.9E+02
3,3-Dichlorobenzidine <sup>C</sup>	0	--	--	na	2.8E-01	--	--	na	7.3E+00	--	--	na	2.8E-02	--	--	na	7.3E-01	--	--	na	7.3E-01	7.3E-01
Dichlorobromomethane <sup>C</sup>	0	--	--	na	1.7E+02	--	--	na	4.4E+03	--	--	na	1.7E+01	--	--	na	4.4E+02	--	--	na	4.4E+02	4.4E+02
1,2-Dichloroethane <sup>C</sup>	0	--	--	na	3.7E+02	--	--	na	9.6E+03	--	--	na	3.7E+01	--	--	na	9.6E+02	--	--	na	9.6E+02	9.6E+02
1,1-Dichloroethylene	0	--	--	na	7.1E+03	--	--	na	1.8E+05	--	--	na	7.1E+02	--	--	na	1.8E+04	--	--	na	1.8E+04	1.8E+04
1,2-trans-dichloroethylene	0	--	--	na	1.0E+04	--	--	na	2.6E+05	--	--	na	1.0E+03	--	--	na	2.6E+04	--	--	na	2.6E+04	2.6E+04
2,4-Dichlorophenol	0	--	--	na	2.9E+02	--	--	na	7.5E+03	--	--	na	2.9E+01	--	--	na	7.5E+02	--	--	na	7.5E+02	7.5E+02
2,4-Dichlorophenoxy acetic acid (2,4-D)	0	--	--	na	--	--	--	na	--	--	--	na	--	--	--	na	--	--	--	na	--	0.0E+00
1,2-Dichloropropane <sup>C</sup>	0	--	--	na	1.5E+02	--	--	na	3.9E+03	--	--	na	1.5E+01	--	--	na	3.9E+02	--	--	na	3.9E+02	3.9E+02
1,3-Dichloropropene <sup>C</sup>	0	--	--	na	2.1E+02	--	--	na	5.5E+03	--	--	na	2.1E+01	--	--	na	5.5E+02	--	--	na	5.5E+02	5.5E+02
Dieldrin <sup>C</sup>	0	2.4E-01	5.6E-02	na	5.4E-04	1.7E+00	1.1E+00	na	1.4E-02	6.0E-02	1.4E-02	na	5.4E-05	4.2E-01	2.7E-01	na	1.4E-03	4.2E-01	2.7E-01	na	1.4E-03	1.4E-03
Diethyl Phthalate	0	--	--	na	4.4E+04	--	--	na	1.1E+06	--	--	na	4.4E+03	--	--	na	1.1E+05	--	--	na	1.1E+05	1.1E+05
2,4-Dimethylphenol	0	--	--	na	8.5E+02	--	--	na	2.2E+04	--	--	na	8.5E+01	--	--	na	2.2E+03	--	--	na	2.2E+03	2.2E+03
Dimethyl Phthalate	0	--	--	na	1.1E+06	--	--	na	2.9E+07	--	--	na	1.1E+05	--	--	na	2.9E+06	--	--	na	2.9E+06	2.9E+06
Di-n-Butyl Phthalate	0	--	--	na	4.5E+03	--	--	na	1.2E+05	--	--	na	4.5E+02	--	--	na	1.2E+04	--	--	na	1.2E+04	1.2E+04
2,4 Dinitrophenol	0	--	--	na	5.3E+03	--	--	na	1.4E+05	--	--	na	5.3E+02	--	--	na	1.4E+04	--	--	na	1.4E+04	1.4E+04
2-Methyl-4,6-Dinitrophenol	0	--	--	na	2.8E+02	--	--	na	7.3E+03	--	--	na	2.8E+01	--	--	na	7.3E+02	--	--	na	7.3E+02	7.3E+02
2,4-Dinitrotoluene <sup>C</sup>	0	--	--	na	3.4E+01	--	--	na	8.8E+02	--	--	na	3.4E+00	--	--	na	8.8E+01	--	--	na	8.8E+01	8.8E+01
Dioxin 2,3,7,8-tetrachlorodibenzo-p-dioxin	0	--	--	na	5.1E-08	--	--	na	1.3E-06	--	--	na	5.1E-09	--	--	na	1.3E-07	--	--	na	1.3E-07	1.3E-07
1,2-Diphenylhydrazine <sup>C</sup>	0	--	--	na	2.0E+00	--	--	na	5.2E+01	--	--	na	2.0E-01	--	--	na	5.2E+00	--	--	na	5.2E+00	5.2E+00
Alpha-Endosulfan	0	2.2E-01	5.6E-02	na	8.9E+01	1.5E+00	1.1E+00	na	2.3E+03	5.5E-02	1.4E-02	na	8.9E+00	3.9E-01	2.7E-01	na	2.3E+02	3.9E-01	2.7E-01	na	2.3E+02	1.5E-01
Beta-Endosulfan	0	2.2E-01	5.6E-02	na	8.9E+01	1.5E+00	1.1E+00	na	2.3E+03	5.5E-02	1.4E-02	na	8.9E+00	3.9E-01	2.7E-01	na	2.3E+02	3.9E-01	2.7E-01	na	2.3E+02	1.5E-01
Alpha + Beta Endosulfan	0	2.2E-01	5.6E-02	--	--	1.5E+00	1.1E+00	--	--	5.5E-02	1.4E-02	--	--	3.9E-01	2.7E-01	--	--	3.9E-01	2.7E-01	--	--	1.5E-01
Endosulfan Sulfate	0	--	--	na	8.9E+01	--	--	na	2.3E+03	--	--	na	8.9E+00	--	--	na	2.3E+02	--	--	na	2.3E+02	2.3E+02
Endrin	0	8.6E-02	3.6E-02	na	6.0E-02	6.0E-01	7.0E-01	na	1.6E+00	2.2E-02	9.0E-03	na	6.0E-03	1.5E-01	1.8E-01	na	1.6E-01	1.5E-01	1.8E-01	na	1.6E-01	6.0E-02
Endrin Aldehyde	0	--	--	na	3.0E-01	--	--	na	7.8E+00	--	--	na	3.0E-02	--	--	na	7.8E-01	--	--	na	7.8E-01	7.8E-01

Parameter (ug/l unless noted)	Background Conc.	Water Quality Criteria				Wasteload Allocations				Antidegradation Baseline				Antidegradation Allocations				Most Limiting Allocations				Method Target Value
		Acute	Chronic	HH (PWS)	HH	Acute	Chronic	HH (PWS)	HH	Acute	Chronic	HH (PWS)	HH	Acute	Chronic	HH (PWS)	HH	Acute	Chronic	HH (PWS)	HH	
Ethylbenzene	0	--	--	na	2.1E+03	--	--	na	5.5E+04	--	--	na	2.1E+02	--	--	na	5.5E+03	--	--	na	5.5E+03	5.5E+03
Fluoranthene	0	--	--	na	1.4E+02	--	--	na	3.6E+03	--	--	na	1.4E+01	--	--	na	3.6E+02	--	--	na	3.6E+02	3.6E+02
Fluorene	0	--	--	na	5.3E+03	--	--	na	1.4E+05	--	--	na	5.3E+02	--	--	na	1.4E+04	--	--	na	1.4E+04	1.4E+04
Foaming Agents	0	--	--	na	--	--	--	na	--	--	--	na	--	--	--	na	--	--	--	na	--	0.0E+00
Guthion	0	--	1.0E-02	na	--	--	2.0E-01	na	--	--	2.5E-03	na	--	--	4.9E-02	na	--	--	4.9E-02	na	--	4.9E-02
Heptachlor <sup>C</sup>	0	5.2E-01	3.8E-03	na	7.9E-04	3.6E+00	7.4E-02	na	2.1E-02	1.3E-01	9.5E-04	na	7.9E-05	9.1E-01	1.9E-02	na	2.1E-03	9.1E-01	1.9E-02	na	2.1E-03	2.1E-03
Heptachlor Epoxide <sup>C</sup>	0	5.2E-01	3.8E-03	na	3.9E-04	3.6E+00	7.4E-02	na	1.0E-02	1.3E-01	9.5E-04	na	3.9E-05	9.1E-01	1.9E-02	na	1.0E-03	9.1E-01	1.9E-02	na	1.0E-03	1.0E-03
Hexachlorobenzene <sup>C</sup>	0	--	--	na	2.9E-03	--	--	na	7.5E-02	--	--	na	2.9E-04	--	--	na	7.5E-03	--	--	na	7.5E-03	7.5E-03
Hexachlorobutadiene <sup>C</sup>	0	--	--	na	1.8E+02	--	--	na	4.7E+03	--	--	na	1.8E+01	--	--	na	4.7E+02	--	--	na	4.7E+02	4.7E+02
Hexachlorocyclohexane																						
Alpha-BHC <sup>C</sup>	0	--	--	na	4.9E-02	--	--	na	1.3E+00	--	--	na	4.9E-03	--	--	na	1.3E-01	--	--	na	1.3E-01	1.3E-01
Hexachlorocyclohexane																						
Beta-BHC <sup>C</sup>	0	--	--	na	1.7E-01	--	--	na	4.4E+00	--	--	na	1.7E-02	--	--	na	4.4E-01	--	--	na	4.4E-01	4.4E-01
Hexachlorocyclohexane																						
Gamma-BHC <sup>C</sup> (Lindane)	0	9.5E-01	na	na	1.8E+00	6.7E+00	--	na	4.7E+01	2.4E-01	--	na	1.8E-01	1.7E+00	--	na	4.7E+00	1.7E+00	--	na	4.7E+00	6.7E-01
Hexachlorocyclopentadiene	0	--	--	na	1.1E+03	--	--	na	2.9E+04	--	--	na	1.1E+02	--	--	na	2.9E+03	--	--	na	2.9E+03	2.9E+03
Hexachloroethane <sup>C</sup>	0	--	--	na	3.3E+01	--	--	na	8.6E+02	--	--	na	3.3E+00	--	--	na	8.6E+01	--	--	na	8.6E+01	8.6E+01
Hydrogen Sulfide	0	--	2.0E+00	na	--	--	3.9E+01	na	--	--	5.0E-01	na	--	--	9.8E+00	na	--	--	9.8E+00	na	--	9.8E+00
Indeno (1,2,3-cd) pyrene <sup>C</sup>	0	--	--	na	1.8E-01	--	--	na	4.7E+00	--	--	na	1.8E-02	--	--	na	4.7E-01	--	--	na	4.7E-01	4.7E-01
Iron	0	--	--	na	--	--	--	na	--	--	--	na	--	--	--	na	--	--	--	na	--	0.0E+00
Isophorone <sup>C</sup>	0	--	--	na	9.6E+03	--	--	na	2.5E+05	--	--	na	9.6E+02	--	--	na	2.5E+04	--	--	na	2.5E+04	2.5E+04
Kepone	0	--	0.0E+00	na	--	--	0.0E+00	na	--	--	0.0E+00	na	--	--	0.0E+00	na	--	--	0.0E+00	na	--	0.0E+00
Lead	0	4.1E+01	3.5E+00	na	--	2.9E+02	6.8E+01	na	--	1.0E+01	8.7E-01	na	--	7.2E+01	1.7E+01	na	--	7.2E+01	1.7E+01	na	--	1.0E+01
Malathion	0	--	1.0E-01	na	--	--	2.0E+00	na	--	--	2.5E-02	na	--	--	4.9E-01	na	--	--	4.9E-01	na	--	4.9E-01
Mercury	0	1.4E+00	7.7E-01	--	--	9.8E+00	1.5E+01	--	--	3.5E-01	1.9E-01	--	--	2.5E+00	3.8E+00	--	--	2.5E+00	3.8E+00	--	--	9.8E-01
Methyl Bromide	0	--	--	na	1.5E+03	--	--	na	3.9E+04	--	--	na	1.5E+02	--	--	na	3.9E+03	--	--	na	3.9E+03	3.9E+03
Methylene Chloride <sup>C</sup>	0	--	--	na	5.9E+03	--	--	na	1.5E+05	--	--	na	5.9E+02	--	--	na	1.5E+04	--	--	na	1.5E+04	1.5E+04
Methoxychlor	0	--	3.0E-02	na	--	--	5.9E-01	na	--	--	7.5E-03	na	--	--	1.5E-01	na	--	--	1.5E-01	na	--	8.8E-02
Mirex	0	--	0.0E+00	na	--	--	0.0E+00	na	--	--	0.0E+00	na	--	--	0.0E+00	na	--	--	0.0E+00	na	--	0.0E+00
Nickel	0.38	9.7E+01	8.6E+00	na	4.6E+03	6.8E+02	1.6E+02	na	1.2E+05	2.5E+01	2.4E+00	na	4.6E+02	1.7E+02	4.0E+01	na	1.2E+04	1.7E+02	4.0E+01	na	1.2E+04	2.4E+01
Nitrate (as N)	0	--	--	na	--	--	--	na	--	--	--	na	--	--	--	na	--	--	--	na	--	0.0E+00
Nitrobenzene	0	--	--	na	6.9E+02	--	--	na	1.8E+04	--	--	na	6.9E+01	--	--	na	1.8E+03	--	--	na	1.8E+03	1.8E+03
N-Nitrosodimethylamine <sup>C</sup>	0	--	--	na	3.0E+01	--	--	na	7.8E+02	--	--	na	3.0E+00	--	--	na	7.8E+01	--	--	na	7.8E+01	7.8E+01
N-Nitrosodiphenylamine <sup>C</sup>	0	--	--	na	6.0E+01	--	--	na	1.6E+03	--	--	na	6.0E+00	--	--	na	1.6E+02	--	--	na	1.6E+02	1.6E+02
N-Nitrosodi-n-propylamine <sup>C</sup>	0	--	--	na	5.1E+00	--	--	na	1.3E+02	--	--	na	5.1E-01	--	--	na	1.3E+01	--	--	na	1.3E+01	1.3E+01
Nonylphenol	0	2.8E+01	6.6E+00	--	--	2.0E+02	1.3E+02	na	--	7.0E+00	1.7E+00	--	--	4.9E+01	3.2E+01	--	--	4.9E+01	3.2E+01	na	--	1.9E+01
Parathion	0	6.5E-02	1.3E-02	na	--	4.6E-01	2.5E-01	na	--	1.6E-02	3.3E-03	na	--	1.1E-01	6.3E-02	na	--	1.1E-01	6.3E-02	na	--	3.8E-02
PCB Total <sup>C</sup>	0	--	1.4E-02	na	6.4E-04	--	2.7E-01	na	1.7E-02	--	3.5E-03	na	6.4E-05	--	6.8E-02	na	1.7E-03	--	6.8E-02	na	1.7E-03	1.7E-03
Pentachlorophenol <sup>C</sup>	0	3.7E+00	2.8E+00	na	3.0E+01	2.6E+01	5.4E+01	na	7.8E+02	9.3E-01	6.9E-01	na	3.0E+00	6.5E+00	1.3E+01	na	7.8E+01	6.5E+00	1.3E+01	na	7.8E+01	2.6E+00
Phenol	0	--	--	na	8.6E+05	--	--	na	2.2E+07	--	--	na	8.6E+04	--	--	na	2.2E+06	--	--	na	2.2E+06	2.2E+06
Pyrene	0	--	--	na	4.0E+03	--	--	na	1.0E+05	--	--	na	4.0E+02	--	--	na	1.0E+04	--	--	na	1.0E+04	1.0E+04
Radionuclides																						
Gross Alpha Activity																						
(pCi/L)	0	--	--	na	--	--	--	na	--	--	--	na	--	--	--	na	--	--	--	na	--	0.0E+00
Beta and Photon Activity																						
(mrem/yr)	0	--	--	na	--	--	--	na	--	--	--	na	--	--	--	na	--	--	--	na	--	0.0E+00
Radium 226 + 228 (pCi/L)	0	--	--	na	--	--	--	na	--	--	--	na	--	--	--	na	--	--	--	na	--	0.0E+00
Uranium (ug/l)	0	--	--	na	--	--	--	na	--	--	--	na	--	--	--	na	--	--	--	na	--	0.0E+00

Parameter (ug/l unless noted)	Background Conc.	Water Quality Criteria				Wasteload Allocations				Antidegradation Baseline				Antidegradation Allocations				Most Limiting Allocations				Method Target Value
		Acute	Chronic	HH (PWS)	HH	Acute	Chronic	HH (PWS)	HH	Acute	Chronic	HH (PWS)	HH	Acute	Chronic	HH (PWS)	HH	Acute	Chronic	HH (PWS)	HH	
Selenium, Total Recoverable	0	2.0E+01	5.0E+00	na	4.2E+03	1.4E+02	9.8E+01	na	1.1E+05	5.0E+00	1.3E+00	na	4.2E+02	3.5E+01	2.4E+01	na	1.1E+04	3.5E+01	2.4E+01	na	1.1E+04	1.4E+01
Silver	0	9.6E-01	--	na	--	6.7E+00	--	na	--	2.4E-01	--	na	--	1.7E+00	--	na	--	1.7E+00	--	na	--	6.7E-01
Sulfate	0	--	--	na	--	--	--	na	--	--	--	na	--	--	--	na	--	--	--	na	--	0.0E+00
1,1,2,2-Tetrachloroethane <sup>C</sup>	0	--	--	na	4.0E+01	--	--	na	1.0E+03	--	--	na	4.0E+00	--	--	na	1.0E+02	--	--	na	1.0E+02	1.0E+02
Tetrachloroethylene <sup>C</sup>	0	--	--	na	3.3E+01	--	--	na	8.6E+02	--	--	na	3.3E+00	--	--	na	8.6E+01	--	--	na	8.6E+01	8.6E+01
Thallium	0	--	--	na	4.7E-01	--	--	na	1.2E+01	--	--	na	4.7E-02	--	--	na	1.2E+00	--	--	na	1.2E+00	1.2E+00
Toluene	0	--	--	na	6.0E+03	--	--	na	1.6E+05	--	--	na	6.0E+02	--	--	na	1.6E+04	--	--	na	1.6E+04	1.6E+04
Total dissolved solids	0	--	--	na	--	--	--	na	--	--	--	na	--	--	--	na	--	--	--	na	--	0.0E+00
Toxaphene <sup>C</sup>	0	7.3E-01	2.0E-04	na	2.8E-03	5.1E+00	3.9E-03	na	7.3E-02	1.8E-01	5.0E-05	na	2.8E-04	1.3E+00	9.8E-04	na	7.3E-03	1.3E+00	9.8E-04	na	7.3E-03	5.9E-04
Tributyltin	0	4.6E-01	7.2E-02	na	--	3.2E+00	1.4E+00	na	--	1.2E-01	1.8E-02	na	--	8.1E-01	3.5E-01	na	--	8.1E-01	3.5E-01	na	--	2.1E-01
1,2,4-Trichlorobenzene	0	--	--	na	7.0E+01	--	--	na	1.8E+03	--	--	na	7.0E+00	--	--	na	1.8E+02	--	--	na	1.8E+02	1.8E+02
1,1,2-Trichloroethane <sup>C</sup>	0	--	--	na	1.6E+02	--	--	na	4.2E+03	--	--	na	1.6E+01	--	--	na	4.2E+02	--	--	na	4.2E+02	4.2E+02
Trichloroethylene <sup>C</sup>	0	--	--	na	3.0E+02	--	--	na	7.8E+03	--	--	na	3.0E+01	--	--	na	7.8E+02	--	--	na	7.8E+02	7.8E+02
2,4,6-Trichlorophenol <sup>C</sup>	0	--	--	na	2.4E+01	--	--	na	6.2E+02	--	--	na	2.4E+00	--	--	na	6.2E+01	--	--	na	6.2E+01	6.2E+01
2-(2,4,5-Trichlorophenoxy) propionic acid (Silvex)	0	--	--	na	--	--	--	na	--	--	--	na	--	--	--	na	--	--	--	na	--	0.0E+00
Vinyl Chloride <sup>C</sup>	0	--	--	na	2.4E+01	--	--	na	6.2E+02	--	--	na	2.4E+00	--	--	na	6.2E+01	--	--	na	6.2E+01	6.2E+01
Zinc	2.55	6.2E+01	5.0E+01	na	2.6E+04	4.2E+02	9.3E+02	na	6.8E+05	1.7E+01	1.4E+01	na	2.6E+03	1.1E+02	2.3E+02	na	6.8E+04	1.1E+02	2.3E+02	na	6.8E+04	4.3E+01

Notes:

- All concentrations expressed as micrograms/liter (ug/l), unless noted otherwise
- Discharge flow is highest monthly average or Form 2C maximum for Industries and design flow for Municipals
- Metals measured as Dissolved, unless specified otherwise
- "C" indicates a carcinogenic parameter
- Regular WLAs are mass balances (minus background concentration) using the % of stream flow entered above under Mixing Information.  
Antidegradation WLAs are based upon a complete mix.
- Antideg. Baseline = (0.25(WQC - background conc.) + background conc.) for acute and chronic  
= (0.1(WQC - background conc.) + background conc.) for human health
- WLAs established at the following stream flows: 1Q10 for Acute, 30Q10 for Chronic Ammonia, 7Q10 for Other Chronic, 30Q5 for Non-carcinogens and Harmonic Mean for Carcinogens. To apply mixing ratios from a model set the stream flow equal to (mixing ratio - 1), effluent flow equal to 1 and 100% mix.

**1.000 MGD DISCHARGE FLOW - STREAM MIX PER "Mix.exe"**

Discharge Flow Used for WQS-WLA Calculations (MG) 1.000				<b><u>Ammonia - Dry Season - Acute</u></b>		<b><u>Ammonia - Dry Season - Chronic</u></b>	
Stream Flows		Total Mix Flows		90th Percentile pH (SU)	7.447	90th Percentile Temp. (deg C)	22.942
<u>Allocated to Mix (MGD)</u>		<u>Stream + Discharge (MGD)</u>		(7.204 - pH)	-0.243	90th Percentile pH (SU)	7.412
	<u>Dry Season</u>	<u>Wet Season</u>	<u>Dry Season</u>	(pH - 7.204)	0.243	MIN	1.656
1Q10	6.000	6.000	7.000	7.000		MAX	22.942
7Q10	18.500	N/A	19.500	N/A	Trout Present Criterion (mg N/L)	(7.688 - pH)	0.276
30Q10	25.000	25.000	26.000	26.000	Trout Absent Criterion (mg N/L)	(pH - 7.688)	-0.276
30Q5	25.000	N/A	26.000	N/A	Trout Present?		
Harm. Mean	25.000	N/A	26.000	N/A	Effective Criterion (mg N/L)		
Annual Avg.	0.000	N/A	1.000	N/A		Early LS Present Criterion (mg N/L)	2.725
						Early LS Absent Criterion (mg N/L)	2.725
						Early Life Stages Present?	y
						Effective Criterion (mg N/L)	2.725
<b><u>Stream/Discharge Mix Values</u></b>				<b><u>Ammonia - Wet Season - Acute</u></b>		<b><u>Ammonia - Wet Season - Chronic</u></b>	
		<u>Dry Season</u>	<u>Wet Season</u>	90th Percentile pH (SU)	7.447	90th Percentile Temp. (deg C)	22.481
1Q10 90th% Temp. Mix (deg C)		23.600	21.886	(7.204 - pH)	-0.243	90th Percentile pH (SU)	7.412
30Q10 90th% Temp. Mix (deg C)		22.942	22.481	(pH - 7.204)	0.243	MIN	1.706
1Q10 90th% pH Mix (SU)		7.447	7.447			MAX	22.481
30Q10 90th% pH Mix (SU)		7.412	7.412	Trout Present Criterion (mg N/L)	14.357	(7.688 - pH)	0.276
1Q10 10th% pH Mix (SU)		6.150	N/A	Trout Absent Criterion (mg N/L)	21.499	(pH - 7.688)	-0.276
7Q10 10th% pH Mix (SU)		6.117	N/A	Trout Present?	n		
		<u>Calculated</u>	<u>Formula Inputs</u>	Effective Criterion (mg N/L)	21.499	Early LS Present Criterion (mg N/L)	2.807
1Q10 Hardness (mg/L as CaCO3)		47.4	47.4			Early LS Absent Criterion (mg N/L)	2.807
7Q10 Hardness (mg/L as CaCO3)		36.3	36.3			Early Life Stages Present?	y

**1.000 MGD DISCHARGE FLOW - COMPLETE STREAM MIX**

Discharge Flow Used for WQS-WLA Calculations (MG) 1.000				<b><u>Ammonia - Dry Season - Acute</u></b>		<b><u>Ammonia - Dry Season - Chronic</u></b>	
100% Stream Flows		Total Mix Flows		90th Percentile pH (SU)	7.447	90th Percentile Temp. (deg C)	22.942
<u>Allocated to Mix (MGD)</u>		<u>Stream + Discharge (MGD)</u>		(7.204 - pH)	-0.243	90th Percentile pH (SU)	7.412
	<u>Dry Season</u>	<u>Wet Season</u>	<u>Dry Season</u>	(pH - 7.204)	0.243	MIN	1.656
1Q10	6.000	6.000	7.000	7.000		MAX	22.942
7Q10	18.500	N/A	19.500	N/A	Trout Present Criterion (mg N/L)	(7.688 - pH)	0.276
30Q10	25.000	25.000	26.000	26.000	Trout Absent Criterion (mg N/L)	(pH - 7.688)	-0.276
30Q5	25.000	N/A	26.000	N/A	Trout Present?		
Harm. Mean	25.000	N/A	26.000	N/A	Effective Criterion (mg N/L)		
Annual Avg.	0.000	N/A	1.000	N/A		Early LS Present Criterion (mg N/L)	2.725
						Early LS Absent Criterion (mg N/L)	2.725
						Early Life Stages Present?	y
						Effective Criterion (mg N/L)	2.725
<b><u>Stream/Discharge Mix Values</u></b>				<b><u>Ammonia - Wet Season - Acute</u></b>		<b><u>Ammonia - Wet Season - Chronic</u></b>	
		<u>Dry Season</u>	<u>Wet Season</u>	90th Percentile pH (SU)	7.447	90th Percentile Temp. (deg C)	22.481
1Q10 90th% Temp. Mix (deg C)		23.600	21.886	(7.204 - pH)	-0.243	90th Percentile pH (SU)	7.412
30Q10 90th% Temp. Mix (deg C)		22.942	22.481	(pH - 7.204)	0.243	MIN	1.706
1Q10 90th% pH Mix (SU)		7.447	7.447			MAX	22.481
30Q10 90th% pH Mix (SU)		7.412	7.412	Trout Present Criterion (mg N/L)	14.357	(7.688 - pH)	0.276
1Q10 10th% pH Mix (SU)		6.150	N/A	Trout Absent Criterion (mg N/L)	21.499	(pH - 7.688)	-0.276
7Q10 10th% pH Mix (SU)		6.117	N/A	Trout Present?	n		
		<u>Calculated</u>	<u>Formula Inputs</u>	Effective Criterion (mg N/L)	21.499	Early LS Present Criterion (mg N/L)	2.807
1Q10 Hardness (mg/L as CaCO3) =		47.429	47.429			Early LS Absent Criterion (mg N/L)	2.807
7Q10 Hardness (mg/L as CaCO3) =		36.256	36.256			Early Life Stages Present?	y

<u>Stream/Discharge Mix Values</u>		
	<u>Acute</u>	<u>Chronic</u>
Hardness	100.00	100.00
Hardness used	100.00	100.00
90th % pH	7.00	7.00
10th % pH	0.78	1.16
90th % Temp (Annual)	23.17	23.07
90th % Temp (Winter)	10.00	10.00
Salinity	14.08	15.72

<u>Ammonia Criteria Determinations</u>			
<u>Freshwater Ammonia Criteria - Annual</u>		<u>Saltwater Ammon. Criteria - Annual</u>	
<u>Duration</u>	<u>NH3-N</u>	<u>Duration</u>	<u>NH3-N</u>
Acute	36.09	Acute	42.45
Chronic - ELS present	3.41	Chronic	6.49
Chronic - ELS absent	3.41		
<u>Freshwater Ammonia Criteria - Winter</u>		<u>Saltwater Ammon. Criteria - Winter</u>	
<u>Duration</u>	<u>NH3-N</u>	<u>Duration</u>	<u>NH3-N</u>
Acute	36.09	Acute	113.04
Chronic - ELS present	5.91	Chronic	17.16
Chronic - ELS absent	7.91		



## FACILITY INFORMATION

**FACILITY:** Ronile, Inc.

**LOCATION:** Rocky Mount, Franklin County

**VPDES PERMIT NUMBER:** VA0076015                      **Expiration Date:** 09/20/18

**SIC CODE/DESCRIPTION:** 2269/Finishers of textiles, not elsewhere classified

**OUTFALLS/FLOWS (MGD):** **Outfall 001** = 0.158 MGD (Maximum 30-day flow).  
Wastewater sources are process wastewater from the dyeing and finishing of nylon, polyester and wool yarn and storm water from a fuel oil tank berm. Treatment includes an aerated lagoon, polymer addition, flocculation, sedimentation, and a plate and frame filter press.

### RECEIVING STREAM/CRITICAL FLOWS/IWC:

Receiving Stream: Pigg River  
River Basin: Roanoke River  
Subbasin: Roanoke River  
Section: 6a  
Class: III  
Special Standards: None

1Q10 = 6.1 MGD      IWCa = 2.56% (Dilution calculated by CORMIX = 7)  
7Q10 = 6.8 MGD      IWCc = 2.29% (Dilution calculated by CORMIX = 19.5)  
30Q5 = 12 MGD  
Harmonic mean = 27 MGD

### FACILITY PROCESS AND TREATMENT:

This facility has six main dye lines at this plant and one smaller scale sample dye line. The yarn is creled and run through a heat setter to bulk-up the yarn and set the width. From the heat setter, yarn is run through the dye machines, which contain a mixture of dye and dye setting chemicals. A steam box sets the dye and finish that was present on the yarn before dyeing is removed by washing, which gives the rinse water a milky appearance. A two-stage counter-current washing method is used. Supposedly, no dye is removed in this step. To dry the yarn, it passes through padded rollers and a dryer. Once dried, the yarn is temporarily stored in J-boxes at the end of the production line, prior to being routed to the mill, where it is spun onto cones and prepared for shipping. Batch dyeing of small cotton blend rugs, that were believed to be the major source of zinc and DDT, was discontinued in April 2013. Small lots of scoured wool dyeing began in August 2013. According to the facility, large amounts of wool were dyed in 2001-2003. The company does not have plans to dye wool in the foreseeable future.

If dyed, finished wool may be treated with Evercide (25% strength of permetherin) and would be applied at 0.014% of dry wool yarn weight, yielding an overall application of permetherin of 1/4th that (or 0.0035%). Ronile has designed and built a special Evercide applicator that would

hold 20 gallons of Evercide and that would only be used when running this wool product. This new applicator does not need to be cleaned out since it is only being used for this wool product. As an added precaution Ronile built a catch basin underneath this new applicator which is sufficient in size to catch the entire contents of the applicator should it leak or spill. The system is engineered so that no permethrin will go to the waste water treatment lagoon/plant.

The wastewater treatment plant receives flow from the production area, as well as on-site storm water and roof drainage from the Therminol boiler room. In 2001, the wastewater treatment plant was upgraded to provide more effective treatment. The 5 MG aerated lagoon was partitioned into two separate areas, 4 MG for aeration and 1 MG for activated sludge. Wastewater flows from the plant into the head of the lagoon, which serves as an equalization (EQ) basin. A baffle curtain in the lagoon separates the EQ basin from the aerator. Daily jar tests are conducted to determine the polymer dose to achieve of a color of 250-350 ADMI.

The supplier of polymers has changed every few years as the facility tries to comply with permit limits for WET and metals. Zetag polymers were used prior to about 2012. Polymer dose varies with the temperature of the aeration basin, which mirrors the seasonal temperature. Floc is settled in a small settling basin.

2012 – 3/17 Southeastern Laboratories polymers used, one failed acute test 3/2015, one failed chronic test 2014

**SElfloc** 1638 replaced Zetag 7197 a dose of 150 to 350 ppm

**SElfloc** 1840B replaced Zetag 8680, a dry polymer, used at a dose of 3 to 7 ppm  
Polymer, Zetag 7867, and a debulking agent, perlite, are added to the sludge prior to pressing in a plate and frame filter press.

***SElfloc** 2012, containing **sodium dimethyl dithiocarbamate**, for zinc precipitation, was discontinued in fall 2012, after its use was shown to result in failed WET tests.*

3/17 – 10/17 Bond Water Technologies polymers used, failed chronic tests August and September 2017

**BondClear 1330-S**, CAS# 25988-97-0, cationic copolymer of epichlorhydrin and dimethyl amine, dose 94.8 ppm, LC50 *D magna* 10 ppm, LD50 Zebra fish 10 ppm, stopped use 10/10/2017, and resumed use on 4/25/2018

**BondClear 400S**, CAS# 12042-91-0, 50% Al chlorohydrate, dose 80 ppm, EC50 FHM 804 ppm, EC50 *C dubia* 33 ppm

**BondClear 2431-90S**, CAS# 124-04-9, cationic polymer, <2% adipic acid, dose 0.4 ppm, LC50 fish 10-100 ppm, EC50 (daphnia) 10-100 ppm. Use stopped on 6/19/18.

10/17 - 4/18 One failed acute test 3/2018.

**BondClear 1330-B** started on 10/10/17 and stopped use on 4/25/18. EC50 *D magna* >10 ppm (w/10% humic acid) CAS# 42751-79-1 25-50% 1,2-Ethanediamine polymer with (chloromethyl)oxirane and N-methylmethanamine.  
**BondClear 400S**, CAS# 12042-91-0, 50% Al chlorohydrate, dose 80 ppm, EC50 FHM 804 ppm, EC50 *C dubia* 33 ppm  
**BondClear 2431-90S**, CAS# 124-04-9, cationic polymer, <2% adipic acid, dose 0.4 ppm, LC50 fish 10-100 ppm, EC50 (daphnia) 10-100 ppm. Use stopped on 6/19/18.

4/18- 6/18 no WET samples

**BondClear 1330-S**, CAS# 25988-97-0, cationic copolymer of epichlorhydrin and dimethyl amine, dose 94.8 ppm, LC50 *D magna* 10 ppm, LD50 Zebra fish 10 ppm, stopped use 10/10/2017, and resumed use on 4/25/2018  
**BondClear 400S**, CAS# 12042-91-0, 50% Al chlorohydrate, dose 80 ppm, EC50 FHM 804 ppm, EC50 *C dubia* 33 ppm  
**BondClear 2431-90S**, CAS# 124-04-9, cationic polymer, <2% adipic acid, dose 0.4 ppm, LC50 fish 10-100 ppm, EC50 (daphnia) 10-100 ppm. Use stopped on 6/19/18.

6/19/18 6/25 acute sample

**BondClear 1330-S**, CAS# 25988-97-0, cationic copolymer of epichlorhydrin and dimethyl amine, dose 94.8 ppm, LC50 *D magna* 10 ppm, LD50 Zebra fish 10 ppm, stopped use 10/10/2017, and resumed use on 4/25/2018  
**BondClear 400S**, CAS# 12042-91-0, 50% Al chlorohydrate, dose 80 ppm, EC50 FHM 804 ppm, EC50 *C dubia* 33 ppm  
**BondClear 3211-50S** (anionic polymer emulsion) started on 6/19/18, replaced 2431-90S, no CAS# listed on SDS, 48H EC50 >100 ppm (daphnia), 96h LC50 >100 ppm (fish)

Sludge from the settling basin is either returned to the aerated lagoon as activated sludge or is pumped to the sludge holding tank. Perlite dust, sodium potassium aluminum silicate, is used a filter aid agent in sludge pressing. Sludge cake is disposed of at the local Franklin County Sanitary Landfill. Supernatant decant from the sludge holding tank and filtrate from the plate filter press are returned to the aeration basin.

Outfall 001 is a six-inch single pipe diffuser that has slots cut into the pipe, with a blind flange at the end. Ports of two different sizes. The Pigg River, at the outfall location, has a sandy bottom, is approximately 35-feet in width. It has a riffle and pool character, with a long pool at the discharge area. The next riffle area is about 0.25 miles downstream. Although the discharge enters the river near the end of a sharp bend, the next half a mile of the river has a slight curve. CORMIX estimates dilution of 7:1 for acute mixing (1Q10) and 19.5:1 for chronic mixing (7Q10).

A WET limit of 3.1 TUa was effective on September 30, 2004, and on September 21, 2012, was reduced to 2.1 TUa. An effluent limit for zinc also became effective in 2012. Zinc was present in

the latex backing of cotton rugs that were batch dyed at the facility. A low pH in part of the dyeing process may have leached zinc from the backing. Cotton rug dyeing was stopped around the end of April 2013. Wool has not been dyed at the facility since August 2015.

Effluent from outfall 001 exhibited chronic toxicity from 2001-3, which was the period of time that large amounts of wool was dyed. If there are major changes in the type or level of production, such as if wool dyeing becomes a bigger portion of the total production at the facility, then the effluent should be recharacterized through quarterly testing should begin. Since a timetable of type of material dyed when each chronic WET test was performed, has not been documented, the type and level of production preceding each WET test should be documented and submitted with each WET report. At current flow rates, the WWTP has about 50 days of storage. Based on 5 day work weeks would be about 10 weeks.

WET limit calculation using GM 00-2012, Appendix D:

From CORMIX Acute dilution = 7; chronic dilution = 19.5

WLAs Acute =  $0.3 \times 7 = 2.1$  TUa; Chronic  $1 \times 19.5 = 19.5$  TUc

Acute to chronic ratio (ACR) from data since 12/2013:

*C. dubia* 7/2014 chronic test,  $ACR = 100/2.5 = 40$

*C. dubia* 9/2017 chronic test,  $ACR = 47/0.6 = 74.5$

Using the geometric mean of 2 actual ACRs = 53.9,  $WLA_{a,c} = 2.1 \times 53.9 = 113.2$

WET limit from WETLIM10 spreadsheet is an NOAEC = 100%

### **WET Requirements:**

Outfall 001 – NOAEC WET limit of 100% using *C. dubia*. The report submittal should include an estimate of type and amount of material dyed during the preceding quarter.

Prior to adding a new process, new fabric or dye or WWTP polymers, acute and chronic WETs test on effluent from jar test of proposed material must pass WET tests using both species.

Table 1 Acute Test Results, Ronile, Inc.; VA0076015, Outfall 001  
**WET = 2.1 TUa** final on 9/21/2012

Test Date	Test Organism	LC <sub>50</sub> (%)	% Survival in 100% effluent	Testing Laboratory
10/29/13 Q1	<i>C. dubia</i>	> 100	100	CBI
02/12/14 Q2	<i>C. dubia</i>	> 100	100	CBI
05/14/14 Q3	<i>C. dubia</i>	52 (1.9 TUa)	30	CBI
7/23/14 <sup>9,10</sup> Q4	<i>C. dubia</i>	> 100	100	CBI
12/12/14 Q5	<i>C. dubia</i>	> 100	100	CBI
03/19/15 <sup>11</sup> Q6	<i>C. dubia</i>	<b>25 (4.0 TUa)</b>	zero	CBI
06/11/15 Q7	<i>C. dubia</i>	> 100	100	CBI
09/23/15 Q8	<i>C. dubia</i>	> 100	90	CBI
10/22/15 Q9	<i>C. dubia</i>	> 100	100	CBI
01/07/16 Q10	<i>C. dubia</i>	> 100	100	CBI
06/09/16 Q11	<i>C. dubia</i>	> 100	100	CBI
09/14/16 Q12	<i>C. dubia</i>	> 100	55	CBI
10/27/16 Q13	<i>C. dubia</i>	> 100	100	CBI
01/06/17 Q14	<i>C. dubia</i>	81 (1.2 TUa)	20	CBI
New polymer use begins				
06/08/17 Q15	<i>C. dubia</i>	> 100	100	CBI
08/23/17 Q16	<i>C. dubia</i>	71 (1.4 TUa)	10	CBI
12/14/17 Q17	<i>C. dubia</i>	70 (1.4 TUa)	0	CBI
3/23/18 Q18	<i>C. dubia</i>	<b>30 (3.3 TUa)</b>	0 in 100% & 69%	CBI
Polymer changed to 3211-50S		(6/19/18).		
6/29/18 Q19	<i>C. dubia</i>	61.6 (1.6 TUa)	0	CBI

Table 2. Chronic Toxicity Test Results for Ronile, Inc.; VA0076015, Outfall 001 – IWC = 2.1%, Endpoint is an NOEC of 5 % (TUc = 20)

Test Date	Test Organism	%NOEC Surv'l	%NOEC Rpro-Grth	TUc	% Survival in 100% Eff	48h LC50	Lab
12/13 Q1	<i>C. dubia</i>	100	10	10	100	>100	CBI
12/13 Q1	<i>P. promelas</i>	100	100	1	90	>100	CBI
02/14 Q2	<i>C. dubia</i>	100	5	20	90	>100	CBI
02/14 Q2	<i>P. promelas</i>	100	100	1	100	>100	CBI
05/14 Q3	<i>C. dubia</i>	20	10	10	0	>100	CBI
05/14 Q3	<i>P. promelas</i>	20	20	5	30	>100	CBI
07/14 <sup>9,10</sup> Q4	<i>C. dubia</i>	20	<b>2.5</b>	<b>40</b>	0	100	CBI
	<b>ACR =</b>	100/2.5	<b>= 40</b>	<b>Ln = 3.68887</b>			
07/14 Q4	<i>P. promelas</i>	20	20	5	72.5	>100	CBI
09/22/15 A1	<i>C. dubia</i>	100	20	5	100	>100	CBI
09/22/15 A1	<i>P. promelas</i>	100	20	5	92.5	>100	CBI
09/22/16 A2	<i>C. dubia</i>	20	20	5	40	>100	CBI
09/22/16 A2	<i>P. promelas</i>	20	20	5	82.5	>100	CBI
08/22/17 A3	<i>C. dubia</i>	20	<b>&lt;2.5</b>	<b>&gt;40</b>	10	>100	CBI
08/22/17 A3	<i>P. promelas</i>	100	20	5	80	>100	CBI
09/26/17 A3	<i>C. dubia</i>	20	<b>0.6</b>	<b>166</b>	0	44.7	CBI
	<b>ACR =</b>	44.7/.6	<b>=74.5</b>	<b>Ln = 5.11199</b>			

1. The TRE plan involved the replacement of the Space Dye Injection Machines with the #7 Dye Line Machines. The Space Dye Injection Machines were removed from the facility in February 2002. Due to the long retention time in the WWTP lagoon (~40 days), the August 2002 test may not be representative of effluent after these machines were removed.
2. Latex-backed [containing zinc] rug dyeing started between February and May of 2005. The 4/2005 passing chronic test may or may not be representative of this operation.
3. Per Ronile fewer latex-backed rugs being dyed in 2010.
4. Time proportional samples, flows varied by 12.5%.
5. Flow composite sampler functional September 13, 2011.
6. Polymer Selfloc XP2012, containing sodium dimethyl dithiocarbamate, for precipitation of zinc, begun August 2012, was believed to be cause of toxicity in September 2012 samples. XP2012 use in the WWTP was stopped around November 2012. Latex-backed rug dyeing was discontinued in April 2013.
7. Wool dyeing, in small quantities, began mid 8/2013, making up about 2.2% of wastewater flow.
8. Feb 2014, wool dyed < 0.01% of total
9. Started flocculation at higher pH in June 2014, after zinc exceeded limit in May 2014.
10. Caustic change to MgOH planned as a result of 7/14 high TUc, per 8/5/14 letter.
11. WET failed 3/2018. Lagoon froze. Sample was brown, which is not typical of effluent (usually pink). COD, ppm; Feb=339, Mar= 295. Ave over past 18 months = 146, 4 highest mos. 12/2014 – 3/2015

## Spreadsheet for determination of WET test endpoints or WET limits

Excel 97  
 Revision Date: 12/13/13  
 File: WETLIM10.xls  
 (MIX.EXE required also)

<b>Acute Endpoint/Permit Limit</b>		<b>Use as LC<sub>50</sub> in Special Condition, as TU<sub>a</sub> on DMR</b>	
<b>ACUTE</b>	100% =	<b>NOAEC</b>	<b>LC<sub>50</sub> = NA</b> % Use as <b>NA</b> TU <sub>a</sub>
<b>ACUTE WLA<sub>a</sub></b>	<b>2.1</b>	Note: Inform the permittee that if the mean of the data exceeds this TU <sub>a</sub> : <b>1.0</b> a limit may result using STATS.EXE	

<b>Chronic Endpoint/Permit Limit</b>		<b>Use as NOEC in Special Condition, as TU<sub>c</sub> on DMR</b>	
<b>CHRONIC</b>	28.52020634 TU <sub>c</sub>	<b>NOEC =</b>	4 % Use as <b>25.00</b> TU <sub>c</sub>
<b>BOTH*</b>	113.2582774 TU <sub>c</sub>	<b>NOEC =</b>	1 % Use as <b>100.00</b> TU <sub>c</sub>
<b>AML</b>	28.52020634 TU <sub>c</sub>	<b>NOEC =</b>	4 % Use as <b>25.00</b> TU <sub>c</sub>

Enter data in the cells with blue type:

Entry Date: 07/25/18  
 Facility Name: RONILE INC  
 VPDES Number: VA0076015  
 Outfall Number: 001

<b>ACUTE WLA<sub>a,c</sub></b>	<b>113.258275</b>	Note: Inform the permittee that if the mean of the data exceeds this TU <sub>c</sub> : <b>11.7202268</b>	
<b>CHRONIC WLA<sub>c</sub></b>	<b>19.5</b>	a limit may result using STATS.EXE	
* Both means acute expressed as chronic			

<b>% Flow to be used from MIX.EXE</b>	<b>Diffuser /modeling study?</b>
Plant Flow: <b>0.158</b> MGD	Enter Y/N <b>y</b>
Acute 1Q10: <b>6.1</b> MGD	Acute <b>7</b> :1
Chronic 7Q10: <b>6.8</b> MGD	Chronic <b>19.5</b> :1

Are data available to calculate CV? (Y/N) **N** (Minimum of 10 data points, same species, needed) Go to Page 2  
 Are data available to calculate ACR? (Y/N) **y** (NOEC<LC50, do not use greater/less than data) Go to Page 3

**NOTE: If the IWCa is >33%, specify the NOAEC = 100% test/endpoint for use**

IWC<sub>a</sub> 14.28571429 % Plant flow/plant flow + 1Q10  
 IWC<sub>c</sub> 5.128205128 % Plant flow/plant flow + 7Q10  
 Dilution, acute 7 100/IWCa  
 Dilution, chronic 19.5 100/IWCc

WLA<sub>a</sub> 2.1 Instream criterion (0.3 TU<sub>a</sub>) X's Dilution, acute  
 WLA<sub>c</sub> 19.5 Instream criterion (1.0 TU<sub>c</sub>) X's Dilution, chronic  
 WLA<sub>a,c</sub> 113.2582746 ACR X's WLA<sub>a</sub> - converts acute WLA to chronic units

ACR -acute/chronic ratio 53.93251173 LC50/NOEC (Default is 10 - if data are available, use tables Page 3)  
 CV-Coefficient of variation 0.6 Default of 0.6 - if data are available, use tables Page 2)

Constants eA 0.4109447 Default = 0.41  
 eB 0.6010373 Default = 0.60  
 eC 2.4334175 Default = 2.43  
 eD 2.4334175 Default = 2.43 (1 samp) No. of samples: 1

\*\*The Maximum Daily Limit is calculated from the lowest LTA, X's eC. The LTA<sub>a,c</sub> and MDL using it are driven by the ACR.

LTA<sub>a,c</sub> 46.54288769 WLA<sub>a,c</sub> X's eA  
 LTA<sub>c</sub> 11.72022735 WLA<sub>c</sub> X's eB  
 MDL\*\* with LTA<sub>a,c</sub> 113.2582774 TU<sub>c</sub> NOEC = 0.882938 (Protects from acute/chronic toxicity) Rounded NOEC's %  
 MDL\*\* with LTA<sub>c</sub> 28.52020634 TU<sub>c</sub> NOEC = 3.506286 (Protects from chronic toxicity) NOEC = 1 %  
 AML with lowest LTA 28.52020634 TU<sub>c</sub> NOEC = 3.506286 Lowest LTA X's eD NOEC = 4 %

IF ONLY ACUTE ENDPOINT/LIMIT IS NEEDED, CONVERT MDL FROM TU<sub>c</sub> to TU<sub>a</sub>

MDL with LTA<sub>a,c</sub> 2.100000051 TU<sub>a</sub> LC50 = 47.619046 % Rounded LC50's %  
 MDL with LTA<sub>c</sub> 0.52881287 TU<sub>a</sub> LC50 = 189.102810 % Use NOAEC=100% LC50 = NA 48 %





**Page 3 - Follow directions to develop a site specific ACR (Acute to Chronic Ratio)**

To determine Acute/Chronic Ratio (ACR), insert usable data below. Usable data is defined as valid paired test results, acute and chronic, tested at the same temperature, same species. The chronic NOEC must be less than the acute LC<sub>50</sub>, since the ACR divides the LC<sub>50</sub> by the NOEC. LC<sub>50</sub>'s >100% should not be used.

**Table 1. ACR using Vertebrate data**

Set #	LC <sub>50</sub>	NOEC	Test ACR	Logarithm	Geomean	Antilog	ACR to Use
1	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	NO DATA
2	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	NO DATA
3	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	NO DATA
4	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	NO DATA
5	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	NO DATA
6	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	NO DATA
7	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	NO DATA
8	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	NO DATA
9	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	NO DATA
10	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	NO DATA

ACR for vertebrate data: 0

Table 1. Result: Vertebrate ACR 0  
 Table 2. Result: Invertebrate ACR 53.93251173  
 Lowest ACR 53.93251173

**Table 2. ACR using Invertebrate data**

Set #	LC <sub>50</sub>	NOEC	Test ACR	Logarithm	Geomean	Antilog	ACR to Use
1	100	2.5	40	3.6888795	3.688879454	40	0
2	44.7	0.6	74.5	4.3107991	3.987733482	53.9325117	53.93251173
3	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	NO DATA
4	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	NO DATA
5	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	NO DATA
6	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	NO DATA
7	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	NO DATA
8	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	NO DATA
9	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	NO DATA
10	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A	NO DATA

ACR for vertebrate data: 53.93251173

**Convert LC<sub>50</sub>'s and NOEC's to Chronic TU's for use in WLA.EXE**  
**ACR used: 53.932512**

**Table 3.**

Enter LC <sub>50</sub>	TUc	Enter NOEC	TUc
1 100	53.932512		NO DATA
2 100	53.932512		NO DATA
3 52	103.716369		NO DATA
4 100	53.932512		NO DATA
5 100	53.932512		NO DATA
6 25	215.730047		NO DATA
7 100	53.932512		NO DATA
8 100	53.932512		NO DATA
9 100	53.932512		NO DATA
10 100	53.932512		NO DATA
11 100	53.932512		NO DATA
12 100	53.932512		NO DATA
13 100	53.932512		NO DATA
14 81	66.583348		NO DATA
15 100	53.932512		NO DATA
16 71	75.961284		NO DATA
17 70	77.046445		NO DATA
18 30	179.775039		NO DATA
19 61.6	87.552779		NO DATA
20	NO DATA		NO DATA

If WLA.EXE determines that an acute limit is needed, you need to convert the TUc answer you get to TUa and then an LC50, enter it here: NO DATA %LC<sub>50</sub>  
 NO DATA TUa

**DILUTION SERIES TO RECOMMEND**

**Table 4.**

	Monitoring % Effluent	TUc	Limit % Effluent	TUc
Dilution series based on data mean	8.5	11.72023		
Dilution series to use for limit			4	25
Dilution factor to recommend:	0.2921003		0.2	
Dilution series to recommend:	100.0	1.00	100.0	1.00
	29.2	3.42	20.0	5.00
	8.5	11.72	4.0	25.00
	2.5	40.12	0.8	125.00
	0.73	137.36	0.2	625.00
Extra dilutions if needed	0.21	470.26	0.0	3125.00
	0.06	1609.93	0.0	15625.00

# APPENDIX D

Documentation from previous permits

Analysis of the RONIL INC. effluent data for  
DISSOLVED COPPER - EFFLUENT CONCENTRATION

The statistics for DISSOLVED COPPER - EFFLUENT CONCENTRATION are:

Number of values = 8  
Quantification level = 10  
Number < quantification = 7  
Expected value = 6.244643  
Variance = 14.0384  
C.V. = .6

Statistics used = Reasonable potential assumptions - Type 1 data

The Standards for DISSOLVED COPPER - EFFLUENT CONCENTRATION are:

Acute Standard = 6.66  
Chronic Standard = 4.64  
Human Health Standard = ----

The 97th percentile of daily values = 15.19582  
The 97th percentile of 4 day averages = 10.38978  
The 97th percentile of 30 day averages = 7.531372

The Acute standard is violated  
The Chronic standard is violated  
The Human health standard is not violated.

DATA

13  
1  
<10  
<10  
1  
1  
6  
7

Analysis of the RONIL, NC. effluent data for COF 2  
Averaging period for standard = 4 days

The statistics for COPPER are:

Number of values	=	1
Quantification level	=	10
Number < quantification	=	0
Expected value	=	12
Variance	=	51.84001
C.V.	=	.6
97th percentile	=	29.20101
Statistics used	=	Reasonable potential assumptions - Type 2 data

The WLAs for COPPER are:

Acute WLA	=	22.01
Chronic WLA	=	63.13
Human Health WLA	=	----

Limits are based on acute toxicity and 1 samples/month, 1 samples/week

Maximum daily limit	=	22.01
Average weekly limit	=	22.01
Average monthly limit	=	22.01

Note: The maximum daily limit applies to industrial dischargers  
The average weekly limit applies to POTWs  
The average monthly limit applies to both.

The Data are  
12

6/9/2008 5:23:50 PM

Facility = Ronile  
Chemical = total Recoverable Zinc  
Chronic averaging period = 4  
WLAa = 141  
WLAc = 544  
Q.L. = 10  
# samples/mo. = 1  
# samples/wk. = 1

Summary of Statistics:

# observations = 1  
Expected Value = 899  
Variance = 290952.  
C.V. = 0.6  
97th percentile daily values = 2187.64  
97th percentile 4 day average = 1495.74  
97th percentile 30 day average = 1084.24  
# < Q.L. = 0  
Model used = BPJ Assumptions, type 2 data

A limit is needed based on Acute Toxicity  
Maximum Daily Limit = 141  
Average Weekly limit = 141  
Average Monthly Limit = 141

The data are:

899

stat zinc 2013

7/9/2013 4:10:57 PM

Facility = Ronile inc  
Chemical = zinc  
Chronic averaging period = 4  
WLAa = 141  
WLAC = 544  
Q.L. = 10  
# samples/mo. = 1  
# samples/wk. = 1

Summary of Statistics:

# observations = 7  
Expected Value = 182.857  
Variance = 12037.2  
C.V. = 0.6  
97th percentile daily values = 444.967  
97th percentile 4 day average = 304.235  
97th percentile 30 day average = 220.535  
# < Q.L. = 0  
Model used = BPJ Assumptions, type 2 data

A limit is needed based on Acute Toxicity  
Maximum Daily Limit = 141  
Average weekly limit = 141  
Average Monthly Limit = 141

The data are:

110  
230  
210  
150  
160  
240  
180

WLA Analysis For:		Ronile, Inc.		ANTIDEGRADATION		Date: 03/10/99		Spreadsheet for Acute AWLAs									
Stream:		Pigg River		Effluent Information		Hardness:		acute		35.403846		Mix Hardness=		acute		35.403846154	
Mean Hardness (mg/L) =		33		Mean Hardness=		58		chronic		35.969121		chronic		35.96912			
Stream NH3 (mg/L)		0		NH3 (mg/L)=				7Q10 Ratio		8.42		* WLAa					
90% Temperature		22.2		90% Temp.=		26		1Q10 Ratio		10.4		Coefficient =		0.1923076923			
90% pH		7.5		90% pH=		8		Harmonic ratio:		34.26		Acute IWC =		0.0961538462			
Fractional 7Q10-MGD		7.42		100% of 7Q10 Flow, MGD=		1.000		30Q5 ratio:		11.91		Chronic IWC =		0.1187648456			
Fractional 1Q10-MGD		9.4															
Harmonic mean (carcinogen):		33.26															
30Q5 Flow (Non-carcinogen):		10.91															
R(iver),L(ake) or S(torm):		R															
Trout Present? (Y/N)		n															
Public Water Supply(Y/N):		n															
				Aquatic Protection		Human Health											
				Freshwater Criteria													
Parameter and Form	Carcinogen?	Sort? (Y/N)	Acute Criteria	Existing Quality at 1Q10	Chronic Criteria	Existing Quality at 7Q10	All Other Surface Water Criteria	Existing Quality for HH	Back-ground concentration	Acute Baseline	Chronic Baseline	Human Health Baseline	Acute AWLA	Chronic A WLA	Human Health A WLA		
Ammonia (mg/l as N)		Y	11.495	0.550	N/A		None			3.2863	N/A	N/A	34.18	N/A	N/A		
Arsenic		Y	None		N/A		50			0.0000	N/A	N/A	N/A	N/A	N/A		
Cadmium		Y	1.22		N/A		None			0.3039	N/A	N/A	3.16	N/A	N/A		
Chloride		Y	860000	9927	N/A		None			222445.2500	N/A	N/A	2313430.60	N/A	N/A		
Chlorine		Y	19		N/A		None			4.7500	N/A	N/A	49.40	N/A	N/A		
Copper		Y	6.66	0.60	N/A		None			2.1159	N/A	N/A	22.01	N/A	N/A		
Cr III		Y	741.91	8.00	N/A		None	8.00		191.4771	N/A	N/A	1916.16	N/A	N/A		
Cr-hex		Y	16		N/A		None			4.0000	N/A	N/A	41.60	N/A	N/A		
Iron		Y	None		N/A		None			0.0000	N/A	N/A	N/A	N/A	N/A		
Lead		Y	31.71	0.30	N/A		None			8.1519	N/A	N/A	84.78	N/A	N/A		
Manganese		Y	None		N/A		None			0.0000	N/A	N/A	N/A	N/A	N/A		
Mercury		Y	2.4		N/A		0.053			0.6000	N/A	N/A	6.24	N/A	N/A		
Nickel		Y	75.91		N/A		4600			18.9772	N/A	N/A	197.36	N/A	N/A		
Selenium		Y	20		N/A		11000			5.0000	N/A	N/A	52.00	N/A	N/A		
Silver		Y	0.68		N/A		None			0.1701	N/A	N/A	1.77	N/A	N/A		
Toluene		Y	1750	1.12	N/A		200000			438.3400	N/A	N/A	4558.74	N/A	N/A		
Xylene		Y	740	0.97	N/A		None			185.7275	N/A	N/A	1931.57	N/A	N/A		
Zinc		Y	48.55	1.89	N/A		None			13.5547	N/A	N/A	140.97	N/A	N/A		
1,1-dichloroethylene		n	None		N/A		17000			0.0000	N/A	N/A	N/A	N/A	N/A		
1,2-dichlorobenzene		n	None		N/A		17000			0.0000	N/A	N/A	N/A	N/A	N/A		



1,2-dichloroethane	C	n	None	N/A	990	0.0000	N/A	N/A	N/A	N/A	N/A	N/A
1,2,4-trichlorobenzene		n	None	N/A	950	0.0000	N/A	N/A	N/A	N/A	N/A	N/A
1,3-dichlorobenzene		n	None	N/A	2600	0.0000	N/A	N/A	N/A	N/A	N/A	N/A
1,4-dichlorobenzene		n	None	N/A	2600	0.0000	N/A	N/A	N/A	N/A	N/A	N/A
2-Chlorophenol		n	None	N/A	400	0.0000	N/A	N/A	N/A	N/A	N/A	N/A
2,4-dichlorophenol		n	None	N/A	790	0.0000	N/A	N/A	N/A	N/A	N/A	N/A
2,4-dichlorophenoxy acetic acid		n	None	N/A	None	0.0000	N/A	N/A	N/A	N/A	N/A	N/A
2,4-dimethylphenol		n	None	N/A	2300	0.0000	N/A	N/A	N/A	N/A	N/A	N/A
2,4-dinitrotoluene	C	n	None	N/A	91	0.0000	N/A	N/A	N/A	N/A	N/A	N/A
2,4,6-Trichlorophenol	C	n	None	N/A	65	0.0000	N/A	N/A	N/A	N/A	N/A	N/A
Acenaphthene		n	None	N/A	2700	0.0000	N/A	N/A	N/A	N/A	N/A	N/A
Aldrin	C	n	3	N/A	0.0014	0.7500	N/A	N/A	7.80	N/A	N/A	N/A
Anthracene		n	None	N/A	110000	0.0000	N/A	N/A	N/A	N/A	N/A	N/A
Antimony		n	None	N/A	4300	0.0000	N/A	N/A	N/A	N/A	N/A	N/A
Arsenic-3		n	360	N/A	None	90.0000	N/A	N/A	936.00	N/A	N/A	N/A
Barium		n	None	N/A	None	0.0000	N/A	N/A	N/A	N/A	N/A	N/A
Benzene	C	n	530	N/A	710	132.5000	N/A	N/A	1378.00	N/A	N/A	N/A
Benzo(a)anthracene	C	n	None	N/A	0.049	0.0000	N/A	N/A	N/A	N/A	N/A	N/A
Benzo(a)pyrene	C	n	None	N/A	0.049	0.0000	N/A	N/A	N/A	N/A	N/A	N/A
Benzo(b)fluoranthene	C	n	None	N/A	0.049	0.0000	N/A	N/A	N/A	N/A	N/A	N/A
Benzo(k)fluoranthene	C	n	None	N/A	0.049	0.0000	N/A	N/A	N/A	N/A	N/A	N/A
Bromoform	C	n	None	N/A	3600	0.0000	N/A	N/A	N/A	N/A	N/A	N/A
Butyl benzyl phthalate		n	None	N/A	5200	0.0000	N/A	N/A	N/A	N/A	N/A	N/A
Carbon Tetrachloride	C	n	None	N/A	45	0.0000	N/A	N/A	N/A	N/A	N/A	N/A
Chlordane	C	n	2.4	N/A	0.0059	0.6000	N/A	N/A	6.24	N/A	N/A	N/A
Chlorodibromomethane		n	None	N/A	57000	0.0000	N/A	N/A	N/A	N/A	N/A	N/A
Chloroform	C	n	None	N/A	47000	0.0000	N/A	N/A	N/A	N/A	N/A	N/A
Chlorpyrifos		n	0.083	N/A	None	0.0208	N/A	N/A	0.22	N/A	N/A	N/A
Chrysene	C	n	None	N/A	0.049	0.0000	N/A	N/A	N/A	N/A	N/A	N/A
Cyanide		n	22	N/A	215000	5.5000	N/A	N/A	57.20	N/A	N/A	N/A
DDD	C	n	None	N/A	0.0084	0.0000	N/A	N/A	N/A	N/A	N/A	N/A
DDE	C	n	None	N/A	0.0059	0.0000	N/A	N/A	N/A	N/A	N/A	N/A
DDT	C	n	1.1	N/A	0.0059	0.2750	N/A	N/A	2.86	N/A	N/A	N/A
Demeton		n	None	N/A	None	0.0000	N/A	N/A	N/A	N/A	N/A	N/A
Di-2-ethylhexyl Phthalate	C	n	None	N/A	59	0.0000	N/A	N/A	N/A	N/A	N/A	N/A
Dibenz(a,h)anthracene	C	n	None	N/A	0.049	0.0000	N/A	N/A	N/A	N/A	N/A	N/A
Dibutyl phthalate		n	None	N/A	12000	0.0000	N/A	N/A	N/A	N/A	N/A	N/A
Dichlorobromomethane	C	n	None	N/A	460	0.0000	N/A	N/A	N/A	N/A	N/A	N/A
Dichloromethane	C	n	None	N/A	16000	0.0000	N/A	N/A	N/A	N/A	N/A	N/A
Dieldrin		n	2.5	N/A	0.00014	0.6250	N/A	N/A	6.50	N/A	N/A	N/A



Diethyl phthalate		n	None	N/A	120000			0.0000	N/A	N/A	N/A	N/A	N/A
Dioxin		n	None	N/A	None			0.0000	N/A	N/A	N/A	N/A	N/A
Dissolved Oxygen		n	4	N/A	None			1.0000	N/A	N/A	10.40	N/A	N/A
Endosulfan		n	0.22	N/A	240			0.0550	N/A	N/A	0.57	N/A	N/A
Endrin		n	0.18	N/A	0.81			0.0450	N/A	N/A	0.47	N/A	N/A
Ethylbenzene		n	3200	N/A	29000			800.0000	N/A	N/A	8320.00	N/A	N/A
Fluoranthene		n	None	N/A	370			0.0000	N/A	N/A	N/A	N/A	N/A
Fluorene		n	None	N/A	14000			0.0000	N/A	N/A	N/A	N/A	N/A
Foaming Agents (MBAS)		n	None	N/A	None			0.0000	N/A	N/A	N/A	N/A	N/A
Guthion		n	None	N/A	None			0.0000	N/A	N/A	N/A	N/A	N/A
Heptachlor	C	n	0.52	N/A	0.0021			0.1300	N/A	N/A	1.35	N/A	N/A
Hexachlorocyclohexane		n	2	N/A	25			0.5000	N/A	N/A	5.20	N/A	N/A
Hydrogen Sulfide		n	None	N/A	None			0.0000	N/A	N/A	N/A	N/A	N/A
Indeno(1,2,3-cd)pyrene	C	n	None	N/A	0.049			0.0000	N/A	N/A	N/A	N/A	N/A
Isophorone		n	None	N/A	490000			0.0000	N/A	N/A	N/A	N/A	N/A
Kepona		n	None	N/A	None			0.0000	N/A	N/A	N/A	N/A	N/A
Lindane		n	2	N/A	25			0.5000	N/A	N/A	5.20	N/A	N/A
Malathion		n	None	N/A	None			0.0000	N/A	N/A	N/A	N/A	N/A
Methoxychlor		n	None	N/A	None			0.0000	N/A	N/A	N/A	N/A	N/A
Mirex		n	None	N/A	None			0.0000	N/A	N/A	N/A	N/A	N/A
Monochlorobenzene		n	None	N/A	21000			0.0000	N/A	N/A	N/A	N/A	N/A
Nitrate(as N)		n	None	N/A	None			0.0000	N/A	N/A	N/A	N/A	N/A
Nitrobenzene		n	None	N/A	1900			0.0000	N/A	N/A	N/A	N/A	N/A
Parathion		n	0.065	N/A	None			0.0163	N/A	N/A	0.17	N/A	N/A
PCBs(7 species)	C	n	None	N/A	0.00045			0.0000	N/A	N/A	N/A	N/A	N/A
Pentachlorophenol		n	0.06	N/A	82			0.0151	N/A	N/A	0.16	N/A	N/A
pH		n	None	N/A	None			0.0000	N/A	N/A	N/A	N/A	N/A
Phenol		n	None	N/A	4600000			0.0000	N/A	N/A	N/A	N/A	N/A
Phosphorus(elemental)		n	None	N/A	None			0.0000	N/A	N/A	N/A	N/A	N/A
Pyrene		n	None	N/A	11000			0.0000	N/A	N/A	N/A	N/A	N/A
Radioactivity		n	None	N/A	None			0.0000	N/A	N/A	N/A	N/A	N/A
Silvex		n	None	N/A	None			0.0000	N/A	N/A	N/A	N/A	N/A
Sulfate		n	None	N/A	None			0.0000	N/A	N/A	N/A	N/A	N/A
Temperature		n	32	N/A	None			8.0000	N/A	N/A	83.20	N/A	N/A
Tetrachloroethylene		n	None	N/A	3500			0.0000	N/A	N/A	N/A	N/A	N/A
Total dissolved solids		n	None	N/A	None			0.0000	N/A	N/A	N/A	N/A	N/A
Toxaphene	C	n	0.73	N/A	0.0075			0.1825	N/A	N/A	1.90	N/A	N/A
Tributyltin		n	0.46	N/A	None			0.1150	N/A	N/A	1.20	N/A	N/A
Trichloroethylene	C	n	None	N/A	810			0.0000	N/A	N/A	N/A	N/A	N/A
Vinyl Chloride		n	None	N/A	5300			0.0000	N/A	N/A	N/A	N/A	N/A

Footnotes:

1. All concentrations expressed as micrograms per liter (ug/L), except Ammonia.
2. Ammonia (as mg/L) selected from separate tables, based on pH and temperature.
3. Acute-1 hour avg. concentration not to be exceeded more than 1/3 years
4. Chronic-4 day avg. concentration not to be exceeded more than 1/3 years.
5. Complete mix-mass balances employ 30Q5 for Non-carcinogens, and Harmonic Mean for Carcinogens
6. All flow values are expressed as Million Gallons per Day.

8. Metals measured as Dissolved, unless specified otherwise.
9. (c)-indicates carcinogenic parameter.
10. Public Water Supply-protects for fish and water consumption.
11. Other Waters-protects for fish consumption only.
12. Hardness expressed as CaCO3 (mg/L).
13. All limitations are based on EPA's TSD Statistical approach.

Freshwater Ammonia Toxicity Standards (based on 9 VAC 25-260-00 et seq)  
(OK as of 3/91)

i. Perform Mass Balance for final Ammonia Concentrations and pH:

	Flow (MGD)	Total NH3-N (mg/L)	pH* SU	Temp. (C)	[H±]
Stream:	9.400	0.000	7.50	22.2	3.16E-08
POTW:	1.000	119.550	8.00	26.0	1.00E-08
Mix:	10.400	11.495	7.53	22.6	2.95E-08

Chronic/Acute Std.? (C/A)--> a <--- = 11.495 mg/l

System MEETS WQ Standard for 1-hour acute ammonia toxicity

\* The pH mix does not take into account alkalinity.

	Acute (1-Hr)
90th Percentile Temp., C:	22.6
90th Percentile pH:	7.53
FT (final temperature):	0.8376
FPH	1.3937
RATIO	NA
pKa	9.32
Un-ionized Ammonia, mg/L as NH3:	0.22
Fraction of Un-ionized Ammonia:	0.0159
Total Ammonia, mg/L as NH3:	13.98
Total Ammonia, mg/L as N:	11.50
Standard Selected	11.495

Freshwater Ammonia Toxicity Standards (based on 9 VAC 25-260-00 et seq)  
(OK as of 3/91)

i. Perform Mass Balance for final Ammonia Concentrations and pH:

	Flow (MGD)	Total NH3-N (mg/L)	pH* SU	Temp. (C)	[H±]
Stream	7.420	0.000	7.50	22.2	3.16E-08
POTW:	1.000	17.306	8.00	26.0	1.00E-08
Mix:	8.420	2.055	7.54	22.7	2.91E-08

Chronic/Acute Std.? (C/A)--> c <--- = 2.055 mg/l

System MEETS WQ Standard for 4-day chronic ammonia toxicity

\* The pH mix does not take into account alkalinity.

	Chronic (4-Day)
90th Percentile Temp., C:	22.7
90th Percentile pH:	7.54
FT (final temperature):	0.832647
FPH	1.383858
RATIO	17.04671
pKa	9.3175
Un-ionized Ammonia, mg/L -NH3:	0.0407
Fraction of Un-ionized Ammonia:	0.01630
Total Ammonia, mg/L as NH3:	2.50
Total Ammonia, mg/L as N:	2.06
Standard Selected	2.055





1,2-dichloroethane	C	n	N/A	None	990	0.0000	0.0000	99	N/A	N/A	22050.60
1,2,4-trichlorobenzene		n	N/A	None	950	0.0000	0.0000	95	N/A	N/A	21159.67
1,3-dichlorobenzene		n	N/A	None	2600	0.0000	0.0000	260	N/A	N/A	19170.67
1,4-dichlorobenzene		n	N/A	None	2600	0.0000	0.0000	260	N/A	N/A	19170.67
2-Chlorophenol		n	N/A	None	400	0.0000	0.0000	40	N/A	N/A	8909.3
2,4-dichlorophenol		n	N/A	None	790	0.0000	0.0000	79	N/A	N/A	17595.93
2,4-dichlorophenoxy acetic acid		n	N/A	None	None	0.0000	0.0000	0	N/A	N/A	N/A
2,4-dimethylphenol		n	N/A	None	2300	0.0000	0.0000	230	N/A	N/A	51228.67
2,4-dinitrotoluene	C	n	N/A	None	91	0.0000	0.0000	9.1	N/A	N/A	2026.87
2,4,6-Trichlorophenol	C	n	N/A	None	65	0.0000	0.0000	6.5	N/A	N/A	1447.77
Acenaphthene		n	N/A	None	2700	0.0000	0.0000	270	N/A	N/A	60138.00
Aldrin	C	n	N/A	0.3	0.0014	0.0000	0.0750	0.00014	N/A	3.79	0.03
Anthracene		n	N/A	None	110000	0.0000	0.0000	11000	N/A	N/A	811066.67
Antimony		n	N/A	None	4300	0.0000	0.0000	430	N/A	N/A	95775.33
Arsenic-3		n	N/A	190	None	0.0000	47.5000	0	N/A	2397.17	N/A
Barium		n	N/A	None	None	0.0000	0.0000	0	N/A	N/A	N/A
Benzene	C	n	N/A	53	710	0.0000	13.2500	71	N/A	668.68	15814.07
Benzo(a)anthracene	C	n	N/A	None	0.049	0.0000	0.0000	0.0049	N/A	N/A	1.09
Benzo(a)pyrene	C	n	N/A	None	0.049	0.0000	0.0000	0.0049	N/A	N/A	1.09
Benzo(b)fluoranthene	C	n	N/A	None	0.049	0.0000	0.0000	0.0049	N/A	N/A	1.09
Benzo(k)fluoranthene	C	n	N/A	None	0.049	0.0000	0.0000	0.0049	N/A	N/A	1.09
Bromoform	C	n	N/A	None	3600	0.0000	0.0000	360	N/A	N/A	80184.00
Butyl benzyl phthalate		n	N/A	None	5200	0.0000	0.0000	520	N/A	N/A	115821.33
Carbon Tetrachloride	C	n	N/A	None	45	0.0000	0.0000	4.5	N/A	N/A	1002.30
Chlordane	C	n	N/A	0.0043	0.0059	0.0000	0.0011	0.00059	N/A	0.05	0.13
Chlorodibromomethane		n	N/A	None	57000	0.0000	0.0000	5700	N/A	N/A	420280.00
Chloroform	C	n	N/A	None	47000	0.0000	0.0000	4700	N/A	N/A	1046846.67
Chlorpyrifos		n	N/A	0.041	None	0.0000	0.0103	0	N/A	0.52	N/A
Chrysene	C	n	N/A	None	0.049	0.0000	0.0000	0.0049	N/A	N/A	1.09
Cyanide		n	N/A	5.2	215000	0.0000	1.3000	21500	N/A	65.61	1585266.67
DDD	C	n	N/A	None	0.0084	0.0000	0.0000	0.00084	N/A	N/A	0.0
DDE	C	n	N/A	None	0.0059	0.0000	0.0000	0.00059	N/A	N/A	0.0
DDT	C	n	N/A	0.001	0.0059	0.0000	0.0003	0.00059	N/A	0.01	0.13
Demeton		n	N/A	0.1	None	0.0000	0.0250	0	N/A	1.26	N/A
Di-2-ethylhexyl Phthalate	C	n	N/A	None	59	0.0000	0.0000	5.9	N/A	N/A	1314.13
Dibenz(a,h)anthracene	C	n	N/A	None	0.049	0.0000	0.0000	0.0049	N/A	N/A	1.09
Dibutyl phthalate		n	N/A	None	12000	0.0000	0.0000	1200	N/A	N/A	267280.00
Dichlorobromomethane	C	n	N/A	None	460	0.0000	0.0000	46	N/A	N/A	10245.73
Dichloromethane	C	n	N/A	None	16000	0.0000	0.0000	1600	N/A	N/A	356373.33
Dieldrin		n	N/A	0.0019	0.00014	0.0000	0.0005	0.000014	N/A	0.02	0.00

Diethyl phthalate		n	N/A	None	120000			0.0000	0.0000	12000	N/A	N/A	2672800.00
Dioxin		n	N/A	None	None			0.0000	0.0000	0	N/A	N/A	N/A
Dissolved Oxygen		n	N/A	5	None			0.0000	1.2500	0	N/A	63.08	N/A
Endosulfan		n	N/A	0.056	240			0.0000	0.0140	24	N/A	0.71	1769.60
Endrin		n	N/A	0.0023	0.81			0.0000	0.0006	0.081	N/A	0.03	5.97
Ethylbenzene		n	N/A	320	29000			0.0000	80.0000	2900	N/A	4037.33	213826.67
Fluoranthene		n	N/A	None	370			0.0000	0.0000	37	N/A	N/A	2728.13
Fluorene		n	N/A	None	14000			0.0000	0.0000	1400	N/A	N/A	103226.67
Foaming Agents (MBAS)		n	N/A	None	None			0.0000	0.0000	0	N/A	N/A	N/A
Guthion		n	N/A	0.01	None			0.0000	0.0025	0	N/A	0.13	N/A
Heptachlor	C	n	N/A	0.0038	0.0021			0.0000	0.0010	0.00021	N/A	0.05	0.05
Hexachlorocyclohexane		n	N/A	0.08	25			0.0000	0.0200		N/A		
Hydrogen Sulfide		n	N/A	2	None			0.0000	0.5000	0	N/A	25.23	N/A
Indeno(1,2,3-cd)pyrene	C	n	N/A	None	0.049			0.0000	0.0000	0.0049	N/A	N/A	1.09
Isophorone		n	N/A	None	490000			0.0000	0.0000	49000	N/A	N/A	3612933.33
Kepone		n	N/A	None	None			0.0000	0.0000	0	N/A	N/A	N/A
Lindane		n	N/A	0.08	25			0.0000	0.0200	2.5	N/A	1.01	184.33
Malathion		n	N/A	0.1	None			0.0000	0.0250	0	N/A	1.26	N/A
Methoxychlor		n	N/A	0.03	None			0.0000	0.0075	0	N/A	0.38	N/A
Mirex		n	N/A	None	None			0.0000	0.0000	0	N/A	N/A	N/A
Monochlorobenzene		n	N/A	None	21000			0.0000	0.0000	2100	N/A	N/A	154840.00
Nitrate(as N)		n	N/A	None	None			0.0000	0.0000	0	N/A	N/A	N/A
Nitrobenzene		n	N/A	None	1900			0.0000	0.0000	190	N/A	N/A	42319.33
Parathion		n	N/A	0.013	None			0.0000	0.0033	0	N/A	0.16	N/A
PCBs(7 species)	C	n	N/A	None	0.00045			0.0000	0.0000	0.000045	N/A	N/A	0.01
Pentachlorophenol		n	N/A	0.04	82			0.0000	0.0095	8.2	N/A	0.48	604.61
pH		n	N/A	None	None			0.0000	0.0000	0	N/A	N/A	N/A
Phenol		n	N/A	None	4600000			0.0000	0.0000	460000	N/A	N/A	33917333.33
Phosphorus(elemental)		n	N/A	None	None			0.0000	0.0000	0	N/A	N/A	N/A
Pyrene		n	N/A	None	11000			0.0000	0.0000	1100	N/A	N/A	81106.67
Radioactivity		n	N/A	None	None			0.0000	0.0000	0	N/A	N/A	N/A
Silvex		n	N/A	None	None			0.0000	0.0000	0	N/A	N/A	N/A
Sulfate		n	N/A	None	None			0.0000	0.0000	0	N/A	N/A	N/A
Temperature		n	N/A	32	None			0.0000	8.0000	0	N/A	403.73	N/A
Tetrachloroethylene		n	N/A	None	3500			0.0000	0.0000	350	N/A	N/A	25806.67
Total dissolved solids		n	N/A	None	None			0.0000	0.0000	0	N/A	N/A	N/A
Toxaphene	C	n	N/A	0.0002	0.0075			0.0000	0.0001	0.00075	N/A	0.00	0.17
Tributyltin		n	N/A	0.026	None			0.0000	0.0065	0	N/A	0.33	N/A
Trichloroethylene	C	n	N/A	None	810			0.0000	0.0000	81	N/A	N/A	18041.40
Vinyl Chloride		n	N/A	None	5300			0.0000	0.0000	530	N/A	N/A	118048.67

Footnotes:

1. All concentrations expressed as micrograms per liter (ug/L), except Ammonia.
2. Ammonia (as mg/L) selected from separate tables based on pH and temperature.
3. Acute-1 hour avg. concentration not to be exceeded more than 1/3 years
4. Chronic-4 day avg. concentration not to be exceeded more than 1/3 years.
5. Complete mix-mass balances employ 30Q5 for Non-carcinogens, and Harmonic Mean for Carcinogens
6. All flow values are expressed as Million Gallons per Day.

8. Metals measured as Dissolved, unless specified otherwise.
9. (c)-indicates carcinogenic parameter.
10. Public Water Supply-protects for fish and water consumption.
11. Other Waters-protects for fish consumption only.
12. Hardness expressed as CaCO3 (mg/L).
13. All limitations are based on EPA's TSD Statistical approach.

Freshwater Ammonia Toxicity Standards (based on 9 VAC 25-260-00 et seq)  
(OK as of 3/91)

I. Perform Mass Balance for final Ammonia Concentrations and pH:

Stream:	Flow (MGD)	Total NH3-N (mg/L)	pH* SU	Temp. (C)	[H+]
Stream:	N/A	0.000	7.50	22.2	3.16E-08
POTW:	0.150	5.624	8.00	26.0	1.00E-08
Mix:	0.150	5.624	8.00	26.0	1.00E-08

Chronic/Acute Std.? (C/A)--> a <-- = 5.624 mg/l

System MEETS WQ Standard for 1-hour acute ammonia toxicity

\* The pH mix does not take into account alkalinity.

	Acute (1-Hr)
90th Percentile Temp., C:	26.0
90th Percentile pH:	8.00
FT (final temperature):	0.6607
FPH	1
RATIO	NA
pKa	9.21
Un-ionized Ammonia, mg/L as NH3:	0.39
Fraction of Un-ionized Ammonia:	0.0575
Total Ammonia, mg/L as NH3:	6.84
Total Ammonia, mg/L as N:	5.62
Standard Selected	5.624

Freshwater Ammonia Toxicity Standards (based on 9 VAC 25-260-00 et seq)  
(OK as of 3/91)

I. Perform Mass Balance for final Ammonia Concentrations and pH:

Stream:	Flow (MGD)	Total NH3-N (mg/L)	pH* SU	Temp. (C)	[H+]
Stream:	7.420	0.000	7.50	22.2	3.16E-08
POTW:	0.150	103.676	8.00	26.0	1.00E-08
Mix:	7.570	2.054	7.51	22.3	3.12E-08

Chronic/Acute Std.? (C/A)--> c <-- = 2.054 mg/l

System MEETS WQ Standard for 4-day chronic ammonia toxicity

\* The pH mix does not take into account alkalinity.

	Chronic (4-Day)
90th Percentile Temp., C:	22.3
90th Percentile pH:	7.51
FT (final temperature):	0.854557
FPH	1.426853
RATIO	17.75053
pKa	9.3293
Un-ionized Ammonia, mg/L -NH3:	0.0370
Fraction of Un-ionized Ammonia:	0.01480
Total Ammonia, mg/L as NH3:	2.50
Total Ammonia, mg/L as N:	2.05
Standard Selected	2.054

# APPENDIX E

TMDL documentation



		Development					
27.	Falling River	Roanoke River PCB TMDL Development	Appomattox, Campbell	L32R	tPCB	0.0	MG/YR
28.	Childrey Creek	Roanoke River PCB TMDL Development	Halifax	L30R	tPCB	0.0	MG/YR
29.	Catawba Creek	Roanoke River PCB TMDL Development	Halifax	L36R	tPCB	0.0	MG/YR
30.	Turnip Creek	Roanoke River PCB TMDL Development	Charlotte	L36R	tPCB	0.0	MG/YR
31.	Hunting Creek	Roanoke River PCB TMDL Development	Halifax	L38R	tPCB	0.0	MG/YR
32.	Cub Creek	Roanoke River PCB TMDL Development	Appomattox, Charlotte	L37R	tPCB	0.0	MG/YR
33.	Black Walnut Creek	Roanoke River PCB TMDL Development	Halifax	L38R	tPCB	0.8	MG/YR
34.	Roanoke Creek	Roanoke River PCB TMDL Development	Charlotte	L39R	tPCB	0.0	MG/YR
35.	Difficult Creek	Roanoke River PCB TMDL Development	Halifax	L41R	tPCB	0.0	MG/YR
36.	Roanoke River	Roanoke River PCB TMDL Development	Appomattox, Campbell, Charlotte, Pittsylvania, Halifax	L19R	tPCB	1,931.8	MG/YR

B. Non-TMDL waste load allocations.

Water Body	Permit No.	Facility Name	Outfall No.	Receiving Stream	River Mile	Parameter Description	WLA	Units WLA
VAW-L04R	VA0072389	Oak Ridge Mobile Home Park	001	Falling Creek UT	0.32	BOD <sub>5</sub>	0.85	KG/D
VAW-L04R	VA0025020	Roanoke City Regional Water Pollution Control Plant	001	Roanoke River	201.81	BOD <sub>5</sub>	1173	KG/D
						TKN, APR-SEP	318	KG/D
						TKN, OCT-MAR	636	KG/D
			001	Roanoke River	201.81	BOD <sub>5</sub>	1173	KG/D
						TKN, APR-SEP	416	KG/D
						TKN, OCT-MAR	832	KG/D



			001	Roanoke River	201.81	BOD <sub>5</sub> TKN, APR-SEP TKN, OCT-MAR	1173 469 939	KG/D KG/D KG/D
VAW-L04R	VA0077895	Roanoke Moose Lodge	001	Mason Creek	7.79	BOD <sub>5</sub> , JUN-SEP TKN, JUN-SEP	0.24 0.09	KG/D KG/D
VAW-L07R	VA0020842	Bedford County School Board-Stewartsville Elementary School	001	Nat Branch, UT	0.59	BOD <sub>5</sub>	0.5	KG/D
VAW-L14R	VA0029254	Ferrum Water and Sewage Auth. - Ferrum Sewage Treatment Plant	001	Storey Creek	9.78	BOD <sub>5</sub>	14.2	KG/D
VAW-L14R	VA0085952	Rocky Mount Town Sewage Treatment Plant	001	Pigg River	52	BOD <sub>5</sub>	133	KG/D
VAW-L14R	VA0076015	Ronile Incorporated	001	Pigg River	57.24	BOD <sub>5</sub>	14.8	KG/D
VAW-L21R	VA0063738	Bedford County School Board - Staunton River High School	001	Shoulder Run, UT	0.95	BOD <sub>5</sub>	1.8	KG/D
VAW-L21R	VA0020869	Bedford County School Board - Thaxton Elementary School	001	Wolf Creek, UT	0.35	BOD <sub>5</sub>	0.31	KG/D
VAW-L22R	VA0023515	Blue Ridge Regional Jail Auth. - Moneta Adult Detention Facility STP	001	Mattox Creek, UT	3.76	BOD <sub>5</sub>	1.66	KG/D
VAW-L25R	VA0020851	Bedford County School Board - Otter River	001	Big Otter River, UT	1.15	BOD <sub>5</sub>	0.4	KG/D